


FUEL REPORT

Sample Rating Trend







ASCENT K2

Component

Diesel Fuel

DIESEL FUEL No. 1 (--- GAL)

DIAGNOS	

Recommendation

We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We advise an early resample to confirm this situation. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Corrosion

The iron level is abnormal.

Contaminants

Appearance is unacceptable. High concentration of visible dirt/debris present in the fuel. There is a high amount of visible silt present in the sample. There is a light concentration of water present in the fuel. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

		-	\$	Sep 2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0798131		
Sample Date		Client Info		28 Sep 2023		
Machine Age	hrs	Client Info		0		
Sample Status				SEVERE		
PHYSICAL PROP	FRTIES	method	limit/base	current	history1	history2
		*ASTM D1298	mint bass			111010172
Specific Gravity	40.4	710111121200		0.851		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500	0.4	L7.0		
Visc @ 40°C	cSt	ASTM D445	2.4	2.62		
Pensky-Martens Flash Point	°C	*PMCC Calculated		60		
SULFUR CONTE	VT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		618		
Sulfur (UVF)	ppm	ASTM D5453		553		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		167		
5% Distillation Point	°C	ASTM D86		196		
10% Distill Point	°C	ASTM D86		208		
15% Distillation Point	°C	ASTM D86		216		
20% Distill Point	°C	ASTM D86		224		
30% Distill Point	°C	ASTM D86		238		
40% Distill Point	°C	ASTM D86		252		
50% Distill Point	°C	ASTM D86		265		
60% Distill Point	°C	ASTM D86		278		
70% Distill Point	°C	ASTM D86		292		
80% Distill Point	°C	ASTM D86		306		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86		326		
95% Distillation Point	°C	ASTM D86		341		
Final Boiling Point	°C	ASTM D86		349		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.5		
IGNITION QUALIT		method	limit/base		hietory1	history2
API Gravity	·-·	ASTM D7777	— IIIIII/Dase	34.8	history1	
Cetane Index		ASTM D7777	<40.0	34.6 43.4		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	0		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	<u>^</u> 0.078		
ppm Water	ppm	ASTM D6304	<500	▲ 783.3		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	1.2		



FUEL REPORT





Certificate L2367

Laboratory Sample No. Lab Number Unique Number

: 05965852 : 10672403

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0798131 Received Diagnosed

: 29 Sep 2023 : 09 Oct 2023 Diagnostician : Doug Bogart

Test Package : DF-2 (Additional Tests: Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

dwayne@kbpowersystemsnc.com

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

KB POWER SYSTEMS LLC

738 Old Buies Creek Rd Lillington, NC US 27546

Contact: DWAYNE REGISTER

T: (919)577-9136

F: