

FUEL REPORT

Sample Rating Trend



ASCENT NB1

Component **Diesel Fuel**

DIESEL FUEL No. 1 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

						,
		_		Sep2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0798126		
Sample Date		Client Info		28 Sep 2023		
Machine Age	hrs	Client Info		0		
Sample Status	1110	Oliotic IIIIo		ATTENTION		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.842		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.0		
Visc @ 40°C	cSt	ASTM D445	2.4	2.53		
Pensky-Martens Flash Point	°C	*PMCC Calculated		58		
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	nnm	ASTM D5185m		45		
Sulfur (UVF)	ppm	ASTM D5165111		45 61		
, ,	phili			VI		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		163		
5% Distillation Point	°C	ASTM D86		191		
10% Distill Point	°C	ASTM D86		201		
15% Distillation Point	°C	ASTM D86		211		
20% Distill Point	°C	ASTM D86		217		
30% Distill Point	°C	ASTM D86		232		
40% Distill Point	°C	ASTM D86		246		
50% Distill Point	°C	ASTM D86		260		
60% Distill Point	°C	ASTM D86		274		
70% Distill Point	°C	ASTM D86		290		
80% Distill Point	°C	ASTM D86		306		
85% Distillation Point	°C	ASTM D86		315		
90% Distill Point	°C	ASTM D86		326		
95% Distillation Point	°C	ASTM D86		342		
Final Boiling Point	°C	ASTM D86		350		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.4		
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.6		
Cetane Index		ASTM D4737	<40.0	47.7		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	0		
Potassium		ASTM D5185m	<0.1	0		
Water	ppm %	ASTM D5765111	<0.1	0.00		
ppm Water		ASTM D6304 ASTM D6304	<500	0.00		
% Gasoline	ppm %	*In-House	<0.50	0.00		
% Biodiesel	%	*In-House	<20.0	2.4		



FUEL REPORT





Laboratory Sample No. Lab Number Unique Number

: WC0798126 : 05965855

: 10672406

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received Diagnosed

: 29 Sep 2023 : 06 Oct 2023

Diagnostician : Doug Bogart

Test Package : DF-2 (Additional Tests: Screen) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

KB POWER SYSTEMS LLC

738 Old Buies Creek Rd Lillington, NC US 27546

Contact: DWAYNE REGISTER dwayne@kbpowersystemsnc.com

T: (919)577-9136

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: