

PROBLEM SUMMARY

Sample Rating Trend

ISO

Machine Id

KAESER SK 15 2435557 (S/N 1004)


Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)



COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	SEVERE					
Particles >6µm	ASTM D7647	>1300	△ 5368						
Particles >14μm	ASTM D7647	>80	639						
Particles >21µm	ASTM D7647	>20	189						
Particles >38µm	ASTM D7647	>4	<u> </u>						
Oil Cleanliness	ISO 4406 (c)	>/17/13	<u>^</u> 21/20/16						

Customer Id: PENWOO Sample No.: KCPA005942 Lab Number: 05966310 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

24 Jan 2020 Diag: Jonathan Hester

WATER




The oil change at the time of sampling has been noted. We recommend you service the filters on this component. We recommend an early resample in 500 hours to monitor this condition. There is too much water present in this sample to perform a particle count. All component wear rates are normal. Excessive free water present. There is a light concentration of water present in the oil. The AN level is acceptable for this fluid.





OIL ANALYSIS REPORT



KAESER SK 15 2435557 (S/N 1004)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jan 2020	Sep2023		
SAMPLE INFORM	AATIONI	method	limit/base		hiotonut	hiotory
	MATION		IIIIII/base	current	history1	history2
Sample Number		Client Info		KCPA005942	KCP22283	
Sample Date	la u a	Client Info		14 Sep 2023	24 Jan 2020	
Machine Age	hrs	Client Info		38429 0	25171 25171	
Oil Age Oil Changed	hrs	Client Info		N/A	Changed	
Sample Status		Ciletit IIIIO		ABNORMAL	SEVERE	
				-		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	3	
Chromium	ppm		>10	0	<1	
Nickel	ppm	ASTM D5185m	>3	<1	<1	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	<1	
Aluminum	ppm	ASTM D5185m		0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm		>50	16	3	
Tin	ppm	ASTM D5185m	>10	0	<1	
Antimony	ppm	ASTM D5185m			0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	<1	
Barium	ppm	ASTM D5185m	90	0	<1	
Molybdenum	ppm	ASTM D5185m		0	<1	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	7	37	
Calcium	ppm	ASTM D5185m	2	0	1	
Phosphorus	ppm	ASTM D5185m		0	5	
Zinc	ppm	ASTM D5185m		50	15	
Sulfur	ppm	ASTM D5185m		18052	17096	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	9	<1	
Sodium	ppm	ASTM D5185m		2	2	
Potassium	ppm	ASTM D5185m	>20	1	1	
Water	%	ASTM D6304	>0.05	0.006	△ 0.239	
ppm Water	ppm	ASTM D6304	>500	65.9	△ 2390	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		13008		
Particles >6µm		ASTM D7647	>1300	5368		
Particles >14μm		ASTM D7647	>80	639		
Particles >21µm		ASTM D7647	>20	189		
Particles >38μm		ASTM D7647	>4	<u> </u>		
Particles >71μm		ASTM D7647	>3	1		
Oil Cleanliness		ISO 4406 (c)	>/17/13	21/20/16		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Sample No. Lab Number **Unique Number**

: 05966310

: KCPA005942 : 10672861

Received : 02 Oct 2023 Diagnosed : 03 Oct 2023 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1954 E MAIN ST WOODLAND, CA

US 95776

Contact: Service Manager

T: F: