# PROBLEM SUMMARY

Sample Rating Trend




ISO

Machine Id
## KAESER BSD 60 7058776 (S/N 1567)
Component
**Compressor**
Fluid
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## COMPONENT CONDITION SUMMARY




## RECOMMENDATION

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

## PROBLEMATIC TEST RESULTS

| Sample Status | | | | ATTENTION | ABNORMAL | ATTENTION |
|---|---|---|---|---|---|---|
| Particles >14µm | | ASTM D7647 | >80 | ▲ **128** | --- | ▲ 103 |
| Particles >21µm | | ASTM D7647 | >20 | ▲ **32** | --- | 18 |
| Oil Cleanliness | | ISO 4406 (c) | >--/17/13 | ▲ **19/17/14** | --- | ▲ 21/18/14 |

**Customer Id:** RMPWYO
**Sample No.:** KC87992
**Lab Number:** 05966326
**Test Package:** IND 2

*To manage this report scan the QR code*

*To discuss the diagnosis or test data:*
Don Baldridge +1
don.b505@comcast.net

*To change component or sample information:*
Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

## RECOMMENDED ACTIONS

| Action | Status | Date | Done By | Description |
|---|---|---|---|---|
| Change Fluid | --- | --- | ? | Oil and filter change at the time of sampling has been noted. |
| Change Filter | --- | --- | ? | Oil and filter change at the time of sampling has been noted. |

## HISTORICAL DIAGNOSIS

**21 Feb 2023 Diag: Don Baldridge**

**VIS DEBRIS**

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**view report**

**11 Aug 2022 Diag: Doug Bogart**

**ISO**

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

**view report**

**30 Jul 2021 Diag: Don Baldridge**

**WATER**

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.All component wear rates are normal. There is a light concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid.

**view report**

KAESER COMPRESSORS
Built for a lifetime.

# OIL ANALYSIS REPORT

Sample Rating Trend




ISO

Machine Id
## KAESER BSD 60 7058776 (S/N 1567)
Component
**Compressor**
Fluid
**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

**▲ Recommendation**
No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

**Wear**
All component wear rates are normal.

**▲ Contamination**
There is a moderate amount of particulates present in the oil.

**Fluid Condition**
The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

| SAMPLE INFORMATION | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Sample Number | | Client Info | | **KC87992** | KC100998 | KC101537 |
| Sample Date | | Client Info | | **07 Sep 2023** | 21 Feb 2023 | 11 Aug 2022 |
| Machine Age | hrs | Client Info | | **17623** | 15840 | 14241 |
| Oil Age | hrs | Client Info | | **3382** | 1599 | 3792 |
| Oil Changed | | Client Info | | **Changed** | Not Changd | Changed |
| Sample Status | | | | **ATTENTION** | ABNORMAL | ATTENTION |

| WEAR METALS | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Iron | ppm | ASTM D5185m | >50 | **2** | 2 | 0 |
| Chromium | ppm | ASTM D5185m | >10 | **0** | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >3 | **<1** | 0 | 0 |
| Titanium | ppm | ASTM D5185m | >3 | **0** | 0 | 0 |
| Silver | ppm | ASTM D5185m | >2 | **0** | 0 | 0 |
| Aluminum | ppm | ASTM D5185m | >10 | **10** | 9 | 3 |
| Lead | ppm | ASTM D5185m | >10 | **0** | <1 | 0 |
| Copper | ppm | ASTM D5185m | >50 | **9** | 4 | <1 |
| Tin | ppm | ASTM D5185m | >10 | **0** | 0 | 0 |
| Antimony | ppm | ASTM D5185m | | **---** | --- | --- |
| Vanadium | ppm | ASTM D5185m | | **0** | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | **0** | 0 | 0 |

| ADDITIVES | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Boron | ppm | ASTM D5185m | | **0** | 0 | 0 |
| Barium | ppm | ASTM D5185m | 90 | **0** | 10 | 0 |
| Molybdenum | ppm | ASTM D5185m | | **0** | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | **0** | <1 | 0 |
| Magnesium | ppm | ASTM D5185m | 90 | **5** | 46 | 0 |
| Calcium | ppm | ASTM D5185m | 2 | **0** | 0 | 0 |
| Phosphorus | ppm | ASTM D5185m | | **34** | 43 | 14 |
| Zinc | ppm | ASTM D5185m | | **39** | 24 | 9 |

| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Silicon | ppm | ASTM D5185m | >25 | **0** | <1 | 0 |
| Sodium | ppm | ASTM D5185m | | **3** | 12 | 1 |
| Potassium | ppm | ASTM D5185m | >20 | **3** | 8 | 0 |
| Water | % | ASTM D6304 | >0.05 | **0.008** | 0.016 | 0.006 |
| ppm Water | ppm | ASTM D6304 | >500 | **81.1** | 166.7 | 61.1 |

| FLUID CLEANLINESS | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|
| Particles >4µm | ASTM D7647 | | **2852** | --- | 17754 |
| Particles >6µm | ASTM D7647 | >1300 | **1064** | --- | ▲ 2461 |
| Particles >14µm | ASTM D7647 | >80 | ▲ **128** | --- | ▲ 103 |
| Particles >21µm | ASTM D7647 | >20 | ▲ **32** | --- | 18 |
| Particles >38µm | ASTM D7647 | >4 | **2** | --- | 1 |
| Particles >71µm | ASTM D7647 | >3 | **0** | --- | 0 |
| Oil Cleanliness | ISO 4406 (c) | >--/17/13 | ▲ **19/17/14** | --- | ▲ 21/18/14 |

| FLUID DEGRADATION | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Acid Number (AN) | mg KOH/g | ASTM D8045 | 0.4 | **0.42** | 0.37 | 0.35 |

KAESER COMPRESSORS
Built for a lifetime.

# OIL ANALYSIS REPORT

Particle Trend




Water (KF)




Acid Number




Water (KF)




Viscosity @ 40°C




| VISUAL | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| White Metal | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Silt | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Debris | scalar | *Visual | NONE | **NONE** | ▲ MODER | NONE |
| Sand/Dirt | scalar | *Visual | NONE | **NONE** | NONE | NONE |
| Appearance | scalar | *Visual | NORML | **NORML** | NORML | NORML |
| Odor | scalar | *Visual | NORML | **NORML** | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | **NEG** | NEG | NEG |
| Free Water | scalar | *Visual | | **NEG** | NEG | NEG |

| FLUID PROPERTIES | | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|---|
| Visc @ 40°C | cSt | ASTM D445 | 46 | **44.5** | 45.2 | 47.9 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---|---|---|---|---|---|
| Color | | |  | | |
| Bottom | | |  | | |

## GRAPHS

Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C




Particle Count




Acid Number




Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513
**Sample No.** : KC87992
**Lab Number** : 05966326
**Unique Number** : 10672877
**Test Package** : IND 2

**Received** : 02 Oct 2023
**Diagnosed** : 03 Oct 2023
**Diagnostician** : Don Baldridge

**R M PALMER**
800 VAN REED RD
WYOMISSING, PA
US 19610
Contact: SERVICE MANAGER

*To discuss this sample report, contact Customer Service at 1-800-237-1369.*
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
*Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)*

T:
F: