


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# Machine Id KAESER SK 20 6342976 (S/N 1101)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

## Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


## **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Sep2018 Apr	2019 Sep2019 Apr2020	Sep2020 Sep2021 Mar2022 Sep20	22 Sep2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124281	KC103870	KC96064
Sample Date		Client Info		23 Sep 2023	07 Sep 2022	15 Mar 2022
Machine Age	hrs	Client Info		22648	18323	16315
Oil Age	hrs	Client Info		0	3993	1985
Oil Changed		Client Info		N/A	Changed	Not Changd
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m		0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		8	6	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	2
Barium	ppm	ASTM D5185m	90	0	2	31
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	90	37	60	64
Calcium	ppm	ASTM D5185m	2	0	1	<1
Phosphorus	ppm	ASTM D5185m		0	5	4
Zinc	ppm	ASTM D5185m		2	<1	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		10	14	14
Potassium	ppm	ASTM D5185m		1	3	0
Water	%	ASTM D6304	>0.05	0.014	0.027	0.020
ppm Water	ppm	ASTM D6304	>500	148.2	274.4	204.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1915	3260	5090
Particles >6μm		ASTM D7647	>1300	602	772	978
Particles >14µm		ASTM D7647	>80	30	46	64
Particles >21μm		ASTM D7647		5	12	17
Particles >38µm		ASTM D7647	>4	1	0	2
Particles >71μm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	18/16/12	19/17/13	17/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.32	0.34	0.38



## **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC124281 : 05966330

: 10672881 : IND 2

: 02 Oct 2023 Received Diagnosed Diagnostician

: 03 Oct 2023 : Don Baldridge 100 KUEBLER RD

EASTON, PA US 18040

Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: