

PROBLEM SUMMARY

WEAR


KAESER 8924531

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status				ABNORMAL						
Aluminum	ppm	ASTM D5185m	>10	1 9						

Sample Rating Trend

Customer Id: LAKLAKNJ Sample No.: KC123041 Lab Number: 05966346 Test Package: IND 2 To manage this report scan the QR code To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS


There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS



OIL ANALYSIS REPORT

DT



Machine Id

KAESER 8924531

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Sep2023		
SAMPLE INFORM	<u>ΛΑΤΙΟΝ</u>	method	limit/base	current	history1	history2
	ALION		IIIIIIVDase			
Sample Number		Client Info		KC123041		
Sample Date	bro	Client Info		27 Sep 2023		
Machine Age Oil Age	hrs	Client Info		4555 0		
Oil Changed	1115	Client Info		N/A		
Sample Status		Ciletit iiiio		ABNORMAL		
				-		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	2		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm		>10	<u> </u>		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm		>50	<1		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	90	2		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	100	<1		
Calcium	ppm	ASTM D5185m	0	0		
Phosphorus	ppm	ASTM D5185m	0	57		
Zinc	ppm	ASTM D5185m	0	3		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1		
Sodium	ppm	ASTM D5185m	720	<1		
Potassium	ppm	ASTM D5185m	>20	6		
Water	%	ASTM D6304	>0.05	0.00		
ppm Water	ppm	ASTM D6304		0.00		
FLUID CLEANLIN		method	limit/base	current	history1	history2
	1200		mmubase			
Particles >4µm Particles >6µm		ASTM D7647 ASTM D7647	>1300	2692 621		
Particles >6µm		ASTM D7647 ASTM D7647	>80	48		
Particles >14µm		ASTM D7647		15		
Particles >21µm		ASTM D7647 ASTM D7647	>20 >4	1		
Particles >30µm		ASTM D7647	>4	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/16/13		
	TIO:	. ,				
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.21		



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** Test Package

: KC123041 : 05966346 : 10672897

Received Diagnosed

: 03 Oct 2023 Diagnostician : Don Baldridge

: 02 Oct 2023

LAKEWOOD COGENERATION LP

123 ENERGY WAY LAKEWOOD, NJ US 08701

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: