




PROBLEM SUMMARY

Sample Rating Trend





WATER



Machine Id
KAESER SFC 37 5961121 (S/N 1074)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) FG-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
Aluminum	ppm	ASTM D5185m	>10	▲ 64	5	▲ 12
Water	%	ASTM D6304	>0.05	▲ 0.229	0.008	0.008
ppm Water	ppm	ASTM D6304	>500	▲ 2290	81.2	84.3
Silt	scalar	*Visual	NONE	▲ MODER	NONE	NONE
Emulsified Water	scalar	*Visual	>0.05	▲ 0.2%	NEG	NEG

Customer Id: REGTOT
Sample No.: KC05966359
Lab Number: 05966359
Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Alert	---	---	?	We were unable to perform a particle count due to a high concentration of particles present in this sample.

HISTORICAL DIAGNOSIS

09 Aug 2023 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



25 Aug 2021 Diag: Don Baldrige

WEAR



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. The aluminum level has decreased, but is still abnormal. All other component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



30 Mar 2021 Diag: Don Baldrige

WEAR



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report



Machine Id
KAESER SFC 37 5961121 (S/N 1074)

Component
Compressor

Fluid
KAESER SIGMA (OEM) FG-460 (--- GAL)



DIAGNOSIS

▲ Recommendation

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

▲ Wear

The aluminum level is abnormal. All other component wear rates are normal.

▲ Contamination

There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			KC05966359	KC123019	KC86460
Sample Date	Client Info			21 Sep 2023	09 Aug 2023	25 Aug 2021
Machine Age	hrs	Client Info		32833	32196	20607
Oil Age	hrs	Client Info		0	0	2435
Oil Changed	Client Info			N/A	N/A	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	20	3	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	▲ 64	5	▲ 12
Lead	ppm	ASTM D5185m	>10	0	<1	2
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m		---	---	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0





ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	2
Barium	ppm	ASTM D5185m		2	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		1	2	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	476	80	236
Zinc	ppm	ASTM D5185m		227	60	134

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m		2	1	2
Potassium	ppm	ASTM D5185m	>20	4	3	1
Water	%	ASTM D6304	>0.05	▲ 0.229	0.008	0.008
ppm Water	ppm	ASTM D6304	>500	▲ 2290	81.2	84.3

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		---	20746	---
Particles >6µm		ASTM D7647	>1300	---	▲ 4807	---
Particles >14µm		ASTM D7647	>80	---	▲ 489	---
Particles >21µm		ASTM D7647	>20	---	▲ 157	---
Particles >38µm		ASTM D7647	>4	---	▲ 9	---
Particles >71µm		ASTM D7647	>3	---	0	---
Oil Cleanliness		ISO 4406 (c)	>--/17/13	---	▲ 22/19/16	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	1.14	0.38	0.715


OIL ANALYSIS REPORT







PARAMETER	VISUAL	method	limit/base	current	history1	history2
White Metal	White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	Debris	scalar	*Visual	NONE	NONE	▲ MODER
Sand/Dirt	Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	Emulsified Water	scalar	*Visual	>0.05	▲ 0.2%	NEG
Free Water	Free Water	scalar	*Visual		▲ NEG	NEG

PARAMETER	FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	Visc @ 40°C	cSt	ASTM D445	46	48.1	46.6

PARAMETER	SAMPLE IMAGES	method	limit/base	current	history1	history2
-----------	---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KC05966359
Lab Number : 05966359
Unique Number : 10672910
Test Package : IND 2

REGAL COMMODITIES
 721 UNION BLVD
 TOTOWA, NJ
 US 07512
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: