


OIL ANALYSIS REPORT

CPL CPL RECOILER-MAIN (S/N 16-4400-0430)

Gearbox

GEAR OIL (PAO) ISO 220 (--- QTS)





Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		RP0038586	RP0035008	RP0034550
Sample Date		Client Info		29 Sep 2023	06 Jun 2023	25 Apr 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184		37	30	55
Iron	ppm	ASTM D5185m	>200	48	21	12
Chromium	ppm	ASTM D5185m	>15	0	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	<1	0	0
Lead	ppm	ASTM D5185m	>100	0	0	0
Copper	ppm	ASTM D5185m	>200	3	4	<1
Tin	ppm	ASTM D5185m	>25	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	25	1	1	21
Barium	ppm	ASTM D5185m	12	0	0	0
Molybdenum	ppm	ASTM D5185m	5	<1	1	<1
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	25	0	2	6
Calcium	ppm	ASTM D5185m	25	5	4	15
Phosphorus	ppm	ASTM D5185m	375	193	184	209
Zinc	ppm	ASTM D5185m	25	4	6	19
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	12	8	2
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	<1
Water	%	ASTM D6304	>0.2	0.010	0.005	0.015
ppm Water	ppm	ASTM D6304	>2000	102.4	50.6	152.8
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.10	0.43	0.46	0.45



OIL ANALYSIS REPORT







Laboratory Sample No. Lab Number

: RP0038586 : 05966426 **Unique Number** : 10672977

Diagnostician Test Package : IND 2 (Additional Tests: PQ)

Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: 02 Oct 2023

: 03 Oct 2023

: Don Baldridge

Received

Diagnosed

OUTOKUMPU STAINLESS USA

HWY 43 N CALVERT, AL US 36513

Contact: MARIO JOHNSON Mario.johnson@outokumpu.com

T: (251)321-4105 F: x: