

# **PROBLEM SUMMARY**

Sample Rating Trend




7008293 (S/N 1277)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

# **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	NORMAL	ATTENTION				
Particles >6µm	ASTM D7647	>1300	<b>2306</b>	582	<b>1</b> 976				
Particles >14µm	ASTM D7647	>80	<b>122</b>	58	<b>1</b> 39				
Particles >21µm	ASTM D7647	>20	<u>^</u> 21	19	<b>△</b> 35				
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>20/18/14</b>	16/13	▲ 18/14				

Customer Id: ADVCUY Sample No.: KC125308 Lab Number: 05967045 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 02 Sep 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 26 Aug 2020 Diag: Doug Bogart

ISO



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






# **OIL ANALYSIS REPORT**

# 7008293 (S/N 1277)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)





# **DIAGNOSIS**

### Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

## Contamination

There is a moderate amount of particulates present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug2020 Sep2021 Sep2023				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC125308	KC98136	KC78886
Sample Date		Client Info		28 Sep 2023	02 Sep 2021	26 Aug 2020
Machine Age	hrs	Client Info		6809	3714	2150
Oil Age	hrs	Client Info		0	1564	2150
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ATTENTION	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	<1	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	6	5	6
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m			0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	13	5
Barium	ppm	ASTM D5185m	90	0	0	<1
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	<1	<1
Magnesium	ppm	ASTM D5185m	90	2	16	19
Calcium	ppm	ASTM D5185m	2	0	0	1
Phosphorus	ppm	ASTM D5185m		2	3	4
Zinc	ppm	ASTM D5185m		2	5	0
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	12	3	<1
Sodium	ppm	ASTM D5185m		0	5	4
Potassium	ppm	ASTM D5185m	>20	<1	<1	<1
Water	%	ASTM D6304	>0.05	0.009	0.011	0.013
ppm Water	ppm	ASTM D6304	>500	94.1	111.5	137.4
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		8896	1937	6736
Particles >6µm		ASTM D7647	>1300	<b>2306</b>	582	<b>△</b> 1976
Particles >14µm		ASTM D7647	>80	<u> </u>	58	<b>△</b> 139
Particles >21µm		ASTM D7647	>20	<u>^</u> 21	19	<b>△</b> 35
Particles >38µm		ASTM D7647	>4	1	2	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/14	16/13	<b>▲</b> 18/14
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.37	0.354	0.382



# **OIL ANALYSIS REPORT**







Certificate L2367

Sample No. Lab Number **Unique Number** 

Test Package

: KC125308 : 05967045 : 10673596

Received Diagnosed

: 02 Oct 2023 : 04 Oct 2023

Diagnostician : Jonathan Hester CUYAHOGA FALLS, OH US 44223

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: IND 2

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: