


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



# 7199125 (S/N 1473)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Α	$\sim$	10	0	10
VA.	G١	XII	15	15
ν×	u.	$^{v}$		$\cdot$

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Feb 2021	Nov2021 Jan2022	May2022 Oct2022	Sep 2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121462	KC104775	KC95140
Sample Date		Client Info		22 Sep 2023	28 Oct 2022	04 May 2022
Machine Age	hrs	Client Info		11304	8378	7056
Oil Age	hrs	Client Info		0	4449	3129
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	<1
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	<1	0
Copper	ppm	ASTM D5185m	>50	2	4	4
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	22	11	16
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	65	58	42
Calcium	ppm	ASTM D5185m	0	2	2	<1
Phosphorus	ppm	ASTM D5185m	0	2	22	9
Zinc	ppm	ASTM D5185m	0	6	5	3
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3	2	5
Sodium	ppm	ASTM D5185m		16	10	10
Potassium	ppm	ASTM D5185m	>20	4	1	<1
Water	%	ASTM D6304	>0.05	0.028	0.019	0.013
ppm Water	ppm	ASTM D6304	>500	282.3	194.5	135.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3226	17391	21188
Particles >6µm		ASTM D7647	>1300	981	<u></u> 5360	<u> 10128</u>
Particles >14µm		ASTM D7647	>80	52	<b>△</b> 305	<b>△</b> 938
Particles >21µm		ASTM D7647	>20	12	<u></u> ▲ 61	<u>▲</u> 105
Particles >38µm		ASTM D7647	>4	0	2	3
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	<u>△</u> 21/20/15	<u>22/21/17</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.35	0.38	0.40



## **OIL ANALYSIS REPORT**



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact: Service Manager