


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id KAESER SK 15 6532183 (S/N 1220)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jul2019 F	eb2020 Aug2020 Feb200	21 Sep2021 Sep2022 Apr2023	Sep2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006430	KCP52488	KCP49027
Sample Date		Client Info		28 Sep 2023	10 Apr 2023	14 Sep 2022
Machine Age	hrs	Client Info		4681	4562	4423
Oil Age	hrs	Client Info		0	0	91
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				NORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	0	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	31	62	65
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	82	92	79
Calcium	ppm	ASTM D5185m	0	1	<1	2
Phosphorus	ppm	ASTM D5185m	0	1	3	1
Zinc	ppm	ASTM D5185m	0	<1	0	1
Sulfur	ppm	ASTM D5185m	23500	22795	23242	20792
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		8	8	10
Potassium	ppm	ASTM D5185m	>20	2	<1	0
Water	%	ASTM D6304	>0.05	0.020	0.016	0.046
ppm Water	ppm	ASTM D6304	>500	205.0	167.4	460.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2775	1466	5028
Particles >6µm		ASTM D7647	>1300	904	360	<u>▲</u> 1343
Particles >14μm		ASTM D7647	>80	38	12	70
Particles >21µm		ASTM D7647	>20	7	1	11
Particles >38µm		ASTM D7647	>4	0	0	1
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/12	18/16/11	<u>△</u> 20/18/13
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number**

: 05967082

: KCPA006430 : 10673633

Received Diagnosed

: 04 Oct 2023 Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

SHAKOPEE, MN

Contact: SERVICE MANAGER

US 55379

T: F: