

PROBLEM SUMMARY

Sample Rating Trend


ISO

Machine Id KAESER SFC 75S 5539895 (S/N 1040)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ATTENTION	NORMAL	NORMAL				
Particles >6µm	ASTM D7647	>1300	1967	450	283				
Particles >14μm	ASTM D7647	>80	147	10	8				
Particles >21µm	ASTM D7647	>20	△ 33	2	1				
Oil Cleanliness	ISO 4406 (c)	>/17/13	20/18/14	18/16/10	18/15/10				

Customer Id: AMASHA Sample No.: KCPA006391 Lab Number: 05967084 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

10 Apr 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



14 Sep 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



23 Mar 2022 Diag: Don Baldridge

150



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER SFC 75S 5539895 (S/N 1040)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Wov2016 Oc	t2017 Sep2018 Feb	2020 Sep 2021 Mar 2022	Apr2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006391	KCPA002819	KCP49030
Sample Date		Client Info		20 Sep 2023	10 Apr 2023	14 Sep 2022
Machine Age	hrs	Client Info		33412	31767	29216
Oil Age	hrs	Client Info		0	0	4594
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				ATTENTION	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m		2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m		2	<1	3
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	2	11	1
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	49	83	33
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	2	7	2
Zinc	ppm	ASTM D5185m	0	9	0	5
Sulfur	ppm	ASTM D5185m	23500	22228	22112	20015
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	<1
Sodium	ppm	ASTM D5185m		18	23	12
Potassium	ppm	ASTM D5185m	>20	5	5	<1
Water	%	ASTM D6304	>0.05	0.017	0.026	0.022
ppm Water	ppm	ASTM D6304	>500	178.3	268.2	226.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6495	2294	1304
Particles >6µm		ASTM D7647	>1300	<u> </u>	450	283
Particles >14μm		ASTM D7647	>80	<u> </u>	10	8
Particles >21µm		ASTM D7647	>20	△ 33	2	1
Particles >38μm		ASTM D7647	>4	1	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/14	18/16/10	18/15/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOH/a	ASTM D8045	1.0	0.35	0.46	0.42

Acid Number (AN)

mg KOH/g ASTM D8045 1.0

0.46

0.35

0.42



OIL ANALYSIS REPORT





Certificate L2367

Laboratory Sample No. Lab Number **Unique Number**

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 05967084

: KCPA006391 : 10673635

Received : 02 Oct 2023 Diagnosed

: 04 Oct 2023

Diagnostician : Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: SERVICE MANAGER? - AMASHA

2601 4TH AVE E

SHAKOPEE, MN

Contact: SERVICE MANAGER

US 55379

T: F: