


PROBLEM SUMMARY

KAESER SFC 75S 5489329 (S/N 1033)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS NORMAL NORMAL Sample Status ABNORMAL Particles >6µm ASTM D7647 >1300 71931 544 349 Particles >14µm ASTM D7647 >80 6050 13 11 1152 3 2 Particles >21µm ASTM D7647 >20 Particles >38µm ASTM D7647 >4 **A** 7 0 0 **Oil Cleanliness** ISO 4406 (c) >--/17/13 **424/23/20** 19/16/11 18/16/11


Customer Id: AMASHA Sample No.: KCPA006397 Lab Number: 05967095 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

10 Apr 2023 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report

15 Sep 2022 Diag: Jonathan Hester



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

23 Mar 2022 Diag: Don Baldridge



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

KAESER SFC 75S 5489329 (S/N 1033)

Compressor Fluid

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006397	KCPA002719	KCP49028
Sample Date		Client Info		20 Sep 2023	10 Apr 2023	15 Sep 2022
Machine Age	hrs	Client Info		33785	31516	29080
Oil Age	hrs	Client Info		0	0	4160
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	0	4
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	10	27	10
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	100	52	89	35
Calcium	ppm	ASTM D5185m	0	1	<1	<1
Phosphorus	ppm	ASTM D5185m	0	2	3	1
Zinc	ppm	ASTM D5185m	0	8	0	4
Sulfur	ppm	ASTM D5185m	23500	21660	22303	20814
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	0	<1
Sodium	ppm	ASTM D5185m		19	25	13
Potassium	ppm	ASTM D5185m	>20	5	5	<1
Water	%	ASTM D6304	>0.05	0.017	0.029	0.022
ppm Water	ppm	ASTM D6304	>500	173.1	295.0	223.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		155527	2870	1908
Particles >6µm		ASTM D7647	>1300	<u> </u>	544	349
Particles >14µm		ASTM D7647	>80	6050	13	11
Particles >21µm		ASTM D7647	>20	<u> </u>	3	2
Particles >38µm		ASTM D7647	>4	<u> </u>	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	4/23/20	19/16/11	18/16/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.35	0.49	0.41


Report Id: AMASHA [WUSCAR] 05967095 (Generated: 10/04/2023 13:26:54) Rev: 1


Contact/Location: SERVICE MANAGER ? - AMASHA




OIL ANALYSIS REPORT








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.3	44.1	43.7
SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						



Bottom



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Page 4 of 4

Certificate L2367