

# **PROBLEM SUMMARY**

# Sample Rating Trend

n2011 Dec2012 Jan2015 Jun2016 Dec2017 EacO110 Listons I date




# FES TYSSED FP 15

Component

**Refrigeration Compressor** 

**USPI ALT-68 SC (210 GAL)** 

# **COMPONENT CONDITION SUMMARY**



# RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	ABNORMAL				
Particles >4µm	ASTM D7647	>10000	<b>26800</b>	5434	<u>4</u> 24681				
Particles >6µm	ASTM D7647	>2500	<b>7917</b>	481	<u> </u>				
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>22/20/15</b>	20/16/12	<b>22/19/13</b>				

**Customer Id: TYSSED** Sample No.: USP0001746 Lab Number: 05967128 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

# **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 17 Aug 2022 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



05 Jun 2022 Diag: Jonathan Hester

ISO



Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



08 Mar 2022 Diag: Doug Bogart

NORMAL




Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



ISO



# FES TYSSED FP 15

**Refrigeration Compressor** 

**USPI ALT-68 SC (210 GAL)** 

# DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

# Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.


# **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Dec2017 Feb2019 Jul2020 J		
SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP0001746	USP242899	USP231530
Sample Date		Client Info		27 Sep 2023	17 Aug 2022	05 Jun 2022
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	<1	<1
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	1	<1	<1
Lead	ppm	ASTM D5185m	>2	0	0	<1
Copper	ppm	ASTM D5185m	>8	0	0	<1
Tin	ppm	ASTM D5185m	>4	0	<1	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	1	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	0
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		0	1	0
Zinc	ppm	ASTM D5185m		0	0	0
Sulfur	ppm	ASTM D5185m	50	14	23	24
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	2	2
Sodium	ppm	ASTM D5185m		0	1	0
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water	%	ASTM D6304	>0.01	0.00	0.007	0.005
ppm Water	ppm	ASTM D6304	>100	0.00	75.8	57.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647	>10000	<b>26800</b>	5434	<b>2</b> 4681
Particles >6µm		ASTM D7647	>2500	<u> </u>	481	▲ 3241
Particles >14μm		ASTM D7647	>320	260	28	63
Particles >21µm		ASTM D7647	>80	34	13	12
Particles >38μm		ASTM D7647	>20	2	0	0
Particles >71µm		ASTM D7647	>4	1	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<u>22/20/15</u>	20/16/12	<u>22/19/13</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



# **OIL ANALYSIS REPORT**







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: 05967128 : 10673679 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : USP0001746 Received Diagnosed Diagnostician

: 02 Oct 2023 : 03 Oct 2023 : Doug Bogart

**TYSON -SEDALIA- USP** 19578 WHITFIELD RD SEDALIA, MO US 65301 Contact: BONNIE bonnie.weathers@tyson.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F: