




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**STAG HILL TOWER 2090036**

Component  
**Diesel Engine**

Fluid  
**DIESEL ENGINE OIL SAE 15W40 (3 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0834369</b>	WC0699381	WCM1384253
Sample Date	Client Info		<b>02 Oct 2023</b>	19 Sep 2022	24 Oct 2017
Machine Age	hrs	Client Info	<b>0</b>	884	686
Oil Age	hrs	Client Info	<b>0</b>	0	20
Oil Changed	Client Info		<b>N/A</b>	Changed	Changed
Sample Status			<b>NORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>2.1	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>51	<b>1</b>	1	1
Chromium	ppm	ASTM D5185m	>11	<b>0</b>	4	<1
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	>3	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>31	<b>2</b>	0	1
Lead	ppm	ASTM D5185m	>26	<b>0</b>	6	3
Copper	ppm	ASTM D5185m	>26	<b>&lt;1</b>	3	<1
Tin	ppm	ASTM D5185m	>4	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m		<b>---</b>	---	12
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	250	<b>25</b>	400	<1
Barium	ppm	ASTM D5185m	10	<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m	100	<b>62</b>	75	69
Manganese	ppm	ASTM D5185m		<b>0</b>	<1	<1
Magnesium	ppm	ASTM D5185m	450	<b>892</b>	360	1044
Calcium	ppm	ASTM D5185m	3000	<b>1057</b>	1448	1165
Phosphorus	ppm	ASTM D5185m	1150	<b>1024</b>	986	1103
Zinc	ppm	ASTM D5185m	1350	<b>1228</b>	1163	1183
Sulfur	ppm	ASTM D5185m	4250	<b>3535</b>	3613	3093

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>22	<b>3</b>	7	3
Sodium	ppm	ASTM D5185m	>158	<b>1</b>	1	2
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	2	2

## INFRA-RED



	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844	>3	<b>0</b>	0.1	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>4.7</b>	5.3	4.
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>17.6</b>	20.1	14.

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>13.5</b>	14.1	10.
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	<b>9.8</b>	9.1	---











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.21	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	14.4	<b>13.6</b>	13.8	13.58

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0834369      **Received** : 03 Oct 2023  
**Lab Number** : **05967365**      **Diagnosed** : 04 Oct 2023  
**Unique Number** : 10673916      **Diagnostician** : Wes Davis  
**Test Package** : MOB 1 ( Additional Tests: TBN )

**GEN TECH LTD**  
 3017 RT 9W  
 NEW WINDSOR, NY  
 US 12553  
 Contact: JOE SAYEGH  
 joe@gentechltd.com  
 T: (845)568-0500  
 F: (845)568-3073

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)