


PROBLEM SUMMARY

HOTLINE/120 MILL 120 TRIMMER 1415-003-0020


Component Gearbox


PETRO CANADA ENDURATEX EP 220 (700 GAL)






COMPONENT CONDITION SUMMARY







RECOMMENDATION

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS								
Sample Status				SEVERE	ABNORMAL	ABNORMAL		
Water	%	ASTM D6304	>0.2	1.41	△ 0.538	▲ 0.282		
ppm Water	ppm	ASTM D6304	>2000	14100	△ 5380	<u>▲</u> 2820		
Particles >4µm		ASTM D7647	>20000	40610		<u>▲</u> 159758		
Particles >6µm		ASTM D7647	>5000	<u>22123</u>		<u>▲</u> 62357		
Particles >14µm		ASTM D7647	>640	△ 3765		4 908		
Particles >21µm		ASTM D7647	>160	1268		43		
Particles >38µm		ASTM D7647	>40	196		1		
Particles >71µm		ASTM D7647	>10	<u> </u>		0		
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<u>23/22/19</u>		2 4/23/17		
Emulsified Water	scalar	*Visual	>0.2	0.2%	△ 0.2%	0.2%		
Visc @ 40°C	cSt	ASTM D445	220	<u> </u>	<u>▲</u> 124	<u></u> 140		

Customer Id: CONMUSAL **Sample No.:** KFS0004888 Lab Number: 05967762 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Water Drain-off			?	We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.			
Resample			?	We recommend an early resample to monitor this condition.			
Check Water Access			?	We advise that you check for the source of water entry.			

HISTORICAL DIAGNOSIS

24 Apr 2023 Diag: Doug Bogart

WATER



We advise that you check for the source of water entry. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition. We were unable to perform a particle count due to a high concentration of particles present in this sample. The aluminum level is abnormal. Appearance is milky. There is a high amount of visible silt present in the sample. There is a moderate concentration of water present in the oil. The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report

27 Mar 2023 Diag: Don Baldridge

WATER



We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is a high amount of particulates present in the oil. There is a light concentration of water present in the oil. The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

view report

28 Feb 2023 Diag: Jonathan Hester

WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. Resample at the next service interval to monitor. All component wear rates are normal. Appearance is hazy. There is a moderate concentration of water present in the oil. The amount and size of particulates present in the system are acceptable. The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.






OIL ANALYSIS REPORT

HOTLINE/120 MILL 120 TRIMMER 1415-003-0020

Component

Gearbox

PETRO CANADA ENDURATEX EP 220 (700 GAL)



DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend an early resample to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. There is a high concentration of water present in the oil.

Fluid Condition

The oil viscosity is lower than normal. Confirm oil type. The AN level is acceptable for this fluid.

0 GAL)		Sep 2022	Nov2022 Jan2023	Feb2023 Mar2023 Apr2023	Sep2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KFS0004888	KFS0003767	KFS0003705
Sample Date		Client Info		29 Sep 2023	24 Apr 2023	27 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	12	58	7
Chromium	ppm	ASTM D5185m	>15	<1	0	0
Nickel	ppm	ASTM D5185m	>15	0	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	24	<u> 88</u>	10
Lead	ppm	ASTM D5185m	>100	0	0	<1
Copper	ppm	ASTM D5185m	>200	<1	<1	<1
Tin	ppm	ASTM D5185m	>25	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		<1	0	1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	60	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1	0
Manganese	ppm	ASTM D5185m	0	<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	1	<1	<1
Calcium	ppm	ASTM D5185m	0	18	13	29
Phosphorus	ppm	ASTM D5185m	270	276	337	294
Zinc	ppm	ASTM D5185m	0	372	390	377
Sulfur	ppm	ASTM D5185m	11200	890	522	901
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	1	<1	<1
Sodium	ppm	ASTM D5185m		5	<1	1
Potassium	ppm	ASTM D5185m	>20	<1	2	1
Water	%	ASTM D6304	>0.2	1.41	△ 0.538	△ 0.282
ppm Water	ppm	ASTM D6304	>2000	14100	▲ 5380	▲ 2820
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>20000	40610		<u>▲</u> 159758
Particles >6µm		ASTM D7647	>5000	<u>22123</u>		<u>▲</u> 62357
Particles >14µm		ASTM D7647	>640	3765		908
Particles >21µm		ASTM D7647	>160	1268		43
Particles >38µm		ASTM D7647	>40	196		1
Particles >71µm		ASTM D7647	>10	<u>^</u> 20		0
Oil Cleanliness		ISO 4406 (c)	>21/19/16	<u>^</u> 23/22/19		<u>△</u> 24/23/17
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.40	0.70	1.04	0.56



OIL ANALYSIS REPORT



Certificate L2367

Unique Number

: 10674313

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: KF, PrtCount)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

: Jonathan Hester

US 35661

Contact: Joel Even

T: (256)740-7490

joel.even@constellium.com