


# **PROBLEM SUMMARY**

# Machine Id SHIGIYA GRINDER 60 Component

Hydraulic System Fluid MOBIL VACUOLINE OIL 1409 (--- GAL)

# COMPONENT CONDITION SUMMARY



# RECOMMENDATION

Resample at the next service interval to monitor. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.

PROBLEMATIC TE	ST RESULTS				
Sample Status			ATTENTION	NORMAL	NORMAL
Particles >4µm	ASTM D7647	>2500	<u> </u>	639	640
Particles >6µm	ASTM D7647	>640	<u> </u>	239	189
Oil Cleanliness	ISO 4406 (c)	>18/16/14	<u> </u>	16/15/12	16/15/11


Customer Id: ZAPDAR Sample No.: ST44972 Lab Number: 05967816 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED	ACTIONS			
Action	Status	Date	Done By	Description
Contact Required			?	Due to an a (201)-444-7

#### on

abnormal test result it is recommended to contact Stauff Corp at -7800 for help resolving the issue.

# **HISTORICAL DIAGNOSIS**





Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report


#### 29 Mar 2023 Diag: Don Baldridge

28 Jun 2023 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

21 Dec 2022 Diag: Don Baldridge









# **OIL ANALYSIS REPORT**

# Sample Rating Trend

Machine Id **SHIGIYA GRINDER 60** Component

**Hydraulic System** MOBIL VACUOLINE OIL 1409 (--- GAL)

# DIAGNOSIS

## Recommendation

Resample at the next service interval to monitor. Due to an abnormal test result it is recommended to contact Stauff Corp at (201)-444-7800 for help resolving the issue.

# Wear

All component wear rates are normal.

## Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

#### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


# ISO


SAMPLE INFORM	<b>IATION</b>	method	limit/base	current	history1	history2
Sample Number		Client Info		ST44972	ST43542	ST44705
Sample Date		Client Info		23 Sep 2023	28 Jun 2023	29 Mar 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	4	4	3
Chromium	ppm	ASTM D5185m		0	0	0
Nickel	ppm	ASTM D5185m	>20	0	<1	0
Titanium	ppm	ASTM D5185m	220	0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	0	<1
Lead		ASTM D5185m	>20	0	0	0
	ppm	ASTM D5185m		1	1	<1
Copper Tin	ppm		>20 >20	0	0	< 1
	ppm		>20	0	0	0
Vanadium Cadmium	ppm	ASTM D5185m ASTM D5185m		0	0	0
	ppm				-	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		<1	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		148	150	187
Zinc	ppm	ASTM D5185m		2	4	0
Sulfur	ppm	ASTM D5185m		11427	10958	13212
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	0	<1
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	<1	<1	0
Water	%	ASTM D6304	>0.05	0.006	0.004	0.001
ppm Water	ppm	ASTM D6304	>500	60.3	48.1	5.1
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	<b>A</b> 2895	639	640
Particles >6µm		ASTM D7647	>640	<u> </u>	239	189
Particles >14µm		ASTM D7647	>160	123	33	18
Particles >21µm		ASTM D7647	>40	43	10	5
Particles >38µm		ASTM D7647	>10	3	1	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>18/16/14	<b>19/17/14</b>	16/15/12	16/15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	2.2	0.89	0.92	0.98





# **OIL ANALYSIS REPORT**
















Color



Bottom

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)



Certificate L2367

Contact/Location: MARK MEDEIROS - ZAPDAR

T: (888)647-3700

F: (508)998-6310