




# PROBLEM SUMMARY

Area  
**(SN55-75/23)**  
 Machine Id  
**SULLAIR Sullair A**  
 Component  
**Screw Compressor**  
 Fluid  
**SULLAIR SULLUBE (7 GAL)**

Sample Rating Trend



## ADDITIVES



### COMPONENT CONDITION SUMMARY

No relevant graphs to display

### RECOMMENDATION

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. ( Customer Sample Comment: Changed oil,air,seperator,genesis filter and oil. Oil linked Shiny like there was brass in it when draining )

### PROBLEMATIC TEST RESULTS

Sample Status				ATTENTION	ABNORMAL	ABNORMAL
Barium	ppm	ASTM D5185m	745	▲ 65	▲ 0	990

Customer Id: GOLEAG  
 Sample No.: WC0765507  
 Lab Number: 05968325  
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:  
 Jonathan Hester +1 919-379-4092 x4092  
[jhester@wearcheckusa.com](mailto:jhester@wearcheckusa.com)

To change component or sample information:  
 Customer Service +1 1-800-237-1369  
[customerservice@wearcheck.com](mailto:customerservice@wearcheck.com)

## RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Fluid	---	---	?	Oil and filter change at the time of sampling has been noted.
Change Filter	---	---	?	Oil and filter change at the time of sampling has been noted.

## HISTORICAL DIAGNOSIS

### 10 Jul 2023 Diag: Don Baldrige

#### WATER



We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. There is a high concentration of water present in the oil. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid.

[view report](#)



### 11 Apr 2023 Diag: Don Baldrige

#### VISUAL METAL



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to metal particles present in this sample. Moderate concentration of visible metal present. All component wear rates are normal. No other contaminants were detected in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.


[view report](#)





# OIL ANALYSIS REPORT

Sample Rating Trend



## ADDITIVES



Area  
**(SN55-75/23)**  
Machine Id  
**SULLAIR Sullair A**  
Component  
**Screw Compressor**  
Fluid  
**SULLAIR SULLUBE (7 GAL)**

### DIAGNOSIS

#### ▲ Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. ( Customer Sample Comment: Changed oil,air,separator,genesis filter and oil. Oil linked Shiney like there was brass in it when draining )

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

#### ▲ Fluid Condition

An additive depletion is indicated. The AN level is acceptable for this fluid.

### SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0765507</b>	WC0765504	WC0765510
Sample Date	Client Info		<b>28 Sep 2023</b>	10 Jul 2023	11 Apr 2023
Machine Age	hrs	Client Info	<b>16998</b>	20135	17981
Oil Age	hrs	Client Info	<b>8000</b>	20135	4803
Oil Changed	Client Info		<b>Changed</b>	Oil Added	Oil Added
Sample Status			<b>ATTENTION</b>	ABNORMAL	ABNORMAL

### WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >60	<b>2</b>	2	2
Chromium	ppm	ASTM D5185m >4	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m	<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >5	<b>0</b>	1	<1
Lead	ppm	ASTM D5185m >10	<b>&lt;1</b>	<1	0
Copper	ppm	ASTM D5185m >30	<b>16</b>	11	1
Tin	ppm	ASTM D5185m >15	<b>&lt;1</b>	<1	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0

### ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 745	<b>▲ 65</b>	<b>▲ 0</b>	990
Molybdenum	ppm	ASTM D5185m 0.0	<b>&lt;1</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m 0.0	<b>7</b>	4	9
Calcium	ppm	ASTM D5185m 1	<b>12</b>	18	13
Phosphorus	ppm	ASTM D5185m 3	<b>36</b>	50	98
Zinc	ppm	ASTM D5185m 0.1	<b>138</b>	107	119
Sulfur	ppm	ASTM D5185m 240	<b>978</b>	1534	1930

### CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >50	<b>2</b>	<1	1
Sodium	ppm	ASTM D5185m	<b>46</b>	14	43
Potassium	ppm	ASTM D5185m >20	<b>4</b>	5	10

### FLUID CLEANLINESS





	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>10000	<b>4247</b>	---	---
Particles >6µm	ASTM D7647	>2500	<b>1343</b>	---	---
Particles >14µm	ASTM D7647	>320	<b>96</b>	---	---
Particles >21µm	ASTM D7647	>80	<b>16</b>	---	---
Particles >38µm	ASTM D7647	>20	<b>0</b>	---	---
Particles >71µm	ASTM D7647	>4	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>19/18/14</b>	---	---

### FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 .06	<b>0.74</b>	0.87	0.71




# OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE ▲ MODER
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	▲ MODER
Debris	scalar	*Visual	NONE	<b>NONE</b>	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	*Visual	>0.1	<b>NEG</b>	0.2% NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	38.1	<b>41.4</b>	41.2 39.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0765507 **Received** : 03 Oct 2023  
**Lab Number** : 05968325 **Diagnosed** : 10 Oct 2023  
**Unique Number** : 10674876 **Diagnostician** : Jonathan Hester  
**Test Package** : IND 2 ( Additional Tests: PrtCount )

**EAGLE GROVE COOP**  
 NW 8TH ST AND MONOE AVE  
 EAGLE GROVE, IA  
 US 50533  
 Contact: TONY SCOTT  
 tscott@goldeaglecoop.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:  
F: