


Area
STEAM AND POWER
 Machine Id
420.0160 RECOVERY FD FAN
 Component
Steam Turbine
 Fluid
SHELL TURBO T ISO 68 (--- GAL)



DIAGNOSIS

Recommendation
 We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear
 All component wear rates are normal.

Contamination
 Appearance is layered. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil.

Fluid Condition
 The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PE0001415	PE0000915	PE0000875
Sample Date	Client Info	20 Sep 2023	21 Apr 2023	21 Apr 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	1	1
Oil Changed	Client Info	N/A	Filtered	Filtered
Sample Status		ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2	
PQ	ASTM D8184	13	12	9	
Iron	ppm	ASTM D5185m >15	<1	0	1
Chromium	ppm	ASTM D5185m >4	0	0	0
Nickel	ppm	ASTM D5185m >2	0	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >10	2	0	0
Lead	ppm	ASTM D5185m	<1	0	0
Copper	ppm	ASTM D5185m >5	<1	0	<1
Tin	ppm	ASTM D5185m >5	0	0	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	0	<1	<1
Magnesium	ppm	ASTM D5185m	0	3	<1
Calcium	ppm	ASTM D5185m	<1	28	3
Phosphorus	ppm	ASTM D5185m	9	11	16
Zinc	ppm	ASTM D5185m	18	6	9
Sulfur	ppm	ASTM D5185m	34	0	129

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	<1	0	0
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	<1	0	0
Water	%	ASTM D6304 >0.03	▲ 0.030	▲ 0.031	---
ppm Water	ppm	ASTM D6304 >300	▲ 300	▲ 310	---





FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >2500	---	931	▲ 6945
Particles >6µm	ASTM D7647 >640	---	507	▲ 2094
Particles >14µm	ASTM D7647 >160	---	86	▲ 175
Particles >21µm	ASTM D7647 >40	---	29	46
Particles >38µm	ASTM D7647 >10	---	4	1
Particles >71µm	ASTM D7647 >3	---	0	0
Oil Cleanliness	ISO 4406 (c) >18/16/14	---	17/16/14	▲ 20/18/15

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 .05	0.079	0.174	0.113


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	▲ LAYRD	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	0.2%	▲ 0.2%
Free Water	scalar	*Visual		NEG	▲ 1.0

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 68	67.0	67.2	67.8

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PE0001415 **Received** : 04 Oct 2023
Lab Number : 05968800 **Diagnosed** : 06 Oct 2023
Unique Number : 10675351 **Diagnostician** : Don Baldrige
Test Package : PLANT (Additional Tests: ICP, KF, KV40, PQ, PrtCount, SCREEN)

Port Townsend Paper Corporation
 100 Mill Rd
 Port Townsend, WA
 US 98368
 Contact: LONNIE LOREE
 lonnie.loree@ptpc.com
 T: (907)738-6506
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)