


PROBLEM SUMMARY

Area **THUNDER SPIRIT [200005313]** Machine Id **41WEA84005 (S/N EWP00759)** Component

Wind Turbine Gearbox

CASTROL OPTIGEAR SYNTHETIC X 320 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status			ABNORMAL	NORMAL	NORMAL			
Particles >6µm	ASTM D7647 :	>2500	<u> </u>	223	1508			
Particles >14µm	ASTM D7647 :	>320	643	21	113			
Particles >21µm	ASTM D7647 :	>80	<u> </u>	8	22			
Oil Cleanliness	ISO 4406 (c)	>/18/15	A 23/21/17	17/15/12	20/18/14			


Customer Id: NORDEX Sample No.: NX013625 Lab Number: 05968979 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>



RECOMMENDED AC	RECOMMENDED ACTIONS					
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		

HISTORICAL DIAGNOSIS

NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



13 Jan 2023 Diag: Don Baldridge

11 Aug 2023 Diag: Doug Bogart





Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the component. The amount and size of particulates present in the system is acceptable. The

AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

VIS DEBRIS



15 Jul 2021 Diag: Don Baldridge

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







OIL ANALYSIS REPORT

Area **THUNDER SPIRIT [200005313]** Machine Id **41WEA84005 (S/N EWP00759)** Component

Wind Turbine Gearbox

CASTROL OPTIGEAR SYNTHETIC X 320 (--- QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX013625	NX013603	NX011622
Sample Date		Client Info		11 Sep 2023	11 Aug 2023	13 Jan 2023
Machine Age	hrs	Client Info		65957	55617	51457
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
PQ		ASTM D8184	>80	12	12	8
Iron	ppm	ASTM D5185m	>150	2	2	2
Chromium	ppm	ASTM D5185m	>5	<1	<1	<1
Nickel	ppm	ASTM D5185m	>10	0	0	<1
Titanium	ppm	ASTM D5185m	>10	0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	3	3	<1
Lead	ppm	ASTM D5185m	>20	0	0	<1
Copper	ppm	ASTM D5185m	>50	<1	<1	<1
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m	>5			
Vanadium	ppm	ASTM D5185m		<1	<1	<1
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	3
Molybdenum	ppm	ASTM D5185m	1150	802	599	612
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		6	4	7
Calcium	ppm	ASTM D5185m	2000	1422	1023	1123
Phosphorus	ppm	ASTM D5185m	400	359	265	328
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	1850	2435	1816	1711
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	10	7	10
Sodium	ppm	ASTM D5185m	>20	9	6	6
Potassium	ppm	ASTM D5185m	>20	2	2	<1
Water	%	ASTM D6304	>0.05	0.025	0.016	0.003
ppm Water	ppm	ASTM D6304	>500	257.8	164.0	36.0
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		51577	998	5577
Particles >6µm		ASTM D7647	>2500	<u> </u>	223	1508
Particles >14µm		ASTM D7647	>320	<u> </u>	21	113
Particles >21µm		ASTM D7647	>80	<u> </u>	8	22
Particles >38µm		ASTM D7647	>20	3	2	2

ASTM D7647 >4

1

ISO 4406 (c) >--/18/15 🔺 23/21/17

Particles >71µm

Oil Cleanliness

17/15/12

1

0


20/18/14





OIL ANALYSIS REPORT


Color


Bottom














Contact/Location: DEREK BRACKEL - NORDEX