

# **PROBLEM SUMMARY**

# Sample Rating Trend


# **WEAR**

# BOX MEZZ NORTH IR (S/N NK2753U16146)

**Air Compressor** 

**USPI AIR 46 (--- GAL)** 

# **COMPONENT CONDITION SUMMARY**



# RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS							
Sample Status				ATTENTION	MARGINAL	MARGINAL	
Copper	ppm	ASTM D5185m	>40	<b>42</b>	<b>4</b> 8	<u>42</u>	

**Customer Id: SMIGRAKY** Sample No.: USPM29847 Lab Number: 05969004 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

# HISTORICAL DIAGNOSIS

# 24 Aug 2023 Diag: Doug Bogart

WEAR



Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 09 Jan 2023 Diag: Doug Bogart

WEAR



No corrective action is recommended at this time. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



# 15 Sep 2022 Diag: Doug Bogart

WEAR



No corrective action is recommended at this time. Resample at the next service interval to monitor. The copper level is abnormal. All other component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

# Sample Rating Trend

# WEAR

Machine Id

# BOX MEZZ NORTH IR (S/N NK2753U16146)

Component

**Air Compressor** 

**USPI AIR 46 (--- GAL)** 

# Fluid

# Recommendation

**DIAGNOSIS** 

Resample at the next service interval to monitor.

### Wear

The copper level is abnormal. All other component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION met			mit/ba						is
K2753U16146)	Apr2017	Jun2018	Apr2019	Sep2020	Apr2021	Feb2022	Jan <sup>2</sup> 023	0et2023	
SIS REPORT									

Sample Number		Client Info		USPM29847	USPM17735	USPM25411
Sample Date		Client Info		03 Oct 2023	24 Aug 2023	09 Jan 2023
Machine Age	hrs	Client Info		0	0	29915
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ATTENTION	MARGINAL	MARGINAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	<1
Chromium	ppm	ASTM D5185m	>4	0	0	0
Nickel	ppm	ASTM D5185m	>4	0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>40	<b>42</b>	<b>4</b> 8	<b>4</b> 2
Tin	ppm	ASTM D5185m	>5	<1	<1	<1
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	1	19	18	20
Zinc	ppm	ASTM D5185m	0	137	132	160
Sulfur	ppm	ASTM D5185m	0	230	248	221
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	<1
Sodium	ppm	ASTM D5185m		<1	<1	0
Potassium	ppm	ASTM D5185m	>20	1	0	0
Water	%	ASTM D6304	>0.2	0.081	0.119	0.042
ppm Water	ppm	ASTM D6304	>2000	816.8	1192.4	428.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	3092	1557	1355
Particles >6µm		ASTM D7647	>2500	773	354	433
Particles >14µm		ASTM D7647	>320	79	27	90
Particles >21µm		ASTM D7647	>80	27	7	34
Particles >38µm		ASTM D7647	>20	1	0	4
Particles >71µm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	19/17/13	18/16/12	18/16/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOU/a			0.53	0.17	0.45

0.53

Acid Number (AN)

mg KOH/g ASTM D8045 0.05

0.17

0.45



# OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No. Lab Number **Unique Number** 

: 05969004 : 10675555 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : 04 Oct 2023 : USPM29847 Received

Diagnosed : 05 Oct 2023 Diagnostician : Doug Bogart

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**SMITHFIELD FOODS - GRAYSON** 

800 C W STEVENS BLVD

GRAYSON, KY

US 41143

Contact:

T: F: