




PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
WWTP GD (S/N WASTE WATER)
 Component
Air Compressor
 Fluid
USPI AIR 46 (--- GAL)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

Sample Status		ATTENTION	SEVERE	NORMAL
Particles >6µm	ASTM D7647 >2500	▲ 2993	▲ 6038	1062
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 20/19/15	▲ 22/20/13	19/17/13

Customer Id: SMIGRAKY
 Sample No.: USPM29846
 Lab Number: 05969005
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Doug Bogart +1 (800)237-1369 x4016
dougb@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

24 Aug 2023 Diag: Doug Bogart

WEAR



Recommend drain oil if not already done and flush with cleaner before refilling with oil. We recommend an early resample to monitor this condition. Bearing and/or bushing wear is indicated. There is a high amount of silt (particulates < 14 microns in size) present in the oil. The AN level is above the recommended limit. The oil viscosity is higher than normal. Confirmed.

view report



09 Jan 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



15 Sep 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
WWTP GD (S/N WASTE WATER)

Component
Air Compressor
Fluid
USPI AIR 46 (--- GAL)

DIAGNOSIS

▲ Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	USPM29846	USPM17744	USPM25416
Sample Date	Client Info	03 Oct 2023	24 Aug 2023	09 Jan 2023
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ATTENTION	SEVERE	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<1	19	0
Chromium	ppm	ASTM D5185m >4	0	0	0
Nickel	ppm	ASTM D5185m >4	0	0	0
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >10	0	1	0
Lead	ppm	ASTM D5185m >20	0	▲ 18	0
Copper	ppm	ASTM D5185m >40	2	● 351	<1
Tin	ppm	ASTM D5185m >5	<1	<1	0
Vanadium	ppm	ASTM D5185m	<1	<1	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	0	17	0
Barium	ppm	ASTM D5185m 0	0	34	1
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m	<1	1	0
Magnesium	ppm	ASTM D5185m 0	0	5	0
Calcium	ppm	ASTM D5185m 0	0	34	0
Phosphorus	ppm	ASTM D5185m 1	76	46	83
Zinc	ppm	ASTM D5185m 0	50	810	65
Sulfur	ppm	ASTM D5185m 0	468	196	620

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<1	2	<1
Sodium	ppm	ASTM D5185m	<1	6	<1
Potassium	ppm	ASTM D5185m >20	1	7	0
Water	%	ASTM D6304 >0.2	0.047	0.010	0.053
ppm Water	ppm	ASTM D6304 >2000	471.8	103.8	535.3


FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	9293	▲ 39484	3416
Particles >6µm	ASTM D7647 >2500	▲ 2993	▲ 6038	1062
Particles >14µm	ASTM D7647 >320	247	67	68
Particles >21µm	ASTM D7647 >80	61	13	10
Particles >38µm	ASTM D7647 >20	4	0	0
Particles >71µm	ASTM D7647 >4	1	0	0
Oil Cleanliness	ISO 4406 (c) >20/18/15	▲ 20/19/15	▲ 22/20/13	19/17/13


FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.05	0.18	● 4.824	0.18


Particle Trend




Water (KF)




Acid Number



Water (KF)



Viscosity @ 40°C



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	LIGHT	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	49.7	45.0	60.5

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------


Color

Bottom




GRAPHS


Ferrous Alloys




Non-ferrous Metals




Viscosity @ 40°C



Particle Count



Acid Number



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : USPM29846
 Lab Number : 05969005
 Unique Number : 10675556
 Test Package : IND 2

SMITHFIELD FOODS - GRAYSON
 800 C W STEVENS BLVD
 GRAYSON, KY
 US 41143
 Contact:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: