


## **PROBLEM SUMMARY**

#### Sample Rating Trend




## RECYCLED NH3

Component

**Refrigeration Compressor** 

USPI ALT-68 SC (--- QTS)

#### **COMPONENT CONDITION SUMMARY**



#### RECOMMENDATION

This is a baseline read-out on the submitted sample.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	NORMAL				
Particles >6µm	ASTM D7647	>2500	<b>13365</b>	260	141				
Oil Cleanliness	ISO 4406 (c)	>/18/15	<b>23/21/15</b>	18/15/11	19/14/12				

Customer Id: TYSCUMGA Sample No.: USP232582 Lab Number: 05969022 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

#### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

#### HISTORICAL DIAGNOSIS

### 24 Sep 2023 Diag: Doug Bogart

NORMAL



This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 07 Sep 2023 Diag: Doug Bogart

NORMAL



This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 31 Aug 2023 Diag: Doug Bogart

NORMAL




This is a baseline read-out on the submitted sample. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service. Viscosity confirmed.





## **OIL ANALYSIS REPORT**

Sample Rating Trend



ISO



# RECYCLED NH3

Component

Refrigeration Compressor

USPI ALT-68 SC (--- QTS)

#### DIAGNOSIS

#### Recommendation

This is a baseline read-out on the submitted sample.

#### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

#### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		n2019 Jan20	20 Oct2020 May2021	Apr2022 Aug2022 Apr2023	Aug2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USP232582	USP232586	USP232585
Sample Date		Client Info		03 Oct 2023	24 Sep 2023	07 Sep 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	<1	2	13
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	<1	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	<1	0	0
Tin	ppm	ASTM D5185m	>4	<1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	0	0
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m		1	0	0
Zinc	ppm	ASTM D5185m		0	0	<1
Sulfur	ppm	ASTM D5185m	50	63	45	17
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	2	<1	<1
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	<1	1	1
Water	%	ASTM D6304	>0.01	0.004	0.006	0.003
ppm Water	ppm	ASTM D6304	>100	49.1	69.6	26.3
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		62975	1886	4092
Particles >6µm		ASTM D7647	>2500	<b>13365</b>	260	141
Particles >14µm		ASTM D7647	>320	179	17	24
Particles >21µm		ASTM D7647	>80	16	4	10
Particles >38μm		ASTM D7647	>20	0	1	0
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/18/15	<u>23/21/15</u>	18/15/11	19/14/12
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D974	0.005	0.014	0.014	0.03



### OIL ANALYSIS REPORT



Diagnosed

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

: Doug Bogart

Report Id: TYSCUMGA [WUSCAR] 05969022 (Generated: 10/05/2023 09:16:16) Rev: 1

Certificate L2367

**Unique Number** 

Test Package

: 10675573

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

: IND 2

Contact/Location: LARRY HOLLAND - TYSCUMGA

US 30130

T:

Contact: LARRY HOLLAND

larryholland@tyson.com

F: (402)423-6661