




# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**HBKM01BE**  
Component  
**Biogas Engine**  
Fluid  
**SHELL MYSELLA S5 S (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor. ( Customer Sample Comment: Top Up Amount: 30 GAL )

### Wear

All component wear rates are normal.

### Contamination

Elemental level of silicon (Si) above normal.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0775335</b>	WC0775337	WC0775340
Sample Date	Client Info		<b>02 Oct 2023</b>	25 Sep 2023	18 Sep 2023
Machine Age	hrs	Client Info	<b>105608</b>	105443	105281
Oil Age	hrs	Client Info	<b>597</b>	432	270
Oil Changed	Client Info		<b>Oil Added</b>	Oil Added	Oil Added
Sample Status			<b>ABNORMAL</b>	NORMAL	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>6</b>	4	3
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	0	0
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	0	0
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>2</b>	4	<1
Lead	ppm	ASTM D5185m	>9	<b>&lt;1</b>	<1	<1
Copper	ppm	ASTM D5185m	>6	<b>2</b>	1	<1
Tin	ppm	ASTM D5185m	>4	<b>4</b>	3	2
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>1</b>	2	1
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>7</b>	6	6
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	0	0
Magnesium	ppm	ASTM D5185m		<b>28</b>	25	28
Calcium	ppm	ASTM D5185m		<b>1598</b>	1538	1569
Phosphorus	ppm	ASTM D5185m	300	<b>341</b>	338	333
Zinc	ppm	ASTM D5185m		<b>403</b>	396	400
Sulfur	ppm	ASTM D5185m		<b>3073</b>	3095	3400

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>▲ 199</b>	156	108
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Potassium	ppm	ASTM D5185m	>20	<b>&lt;1</b>	0	<1

## INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0</b>	0	0
Nitration	Abs/cm	*ASTM D7624	>20	<b>4.8</b>	4.6	5.2
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>20.5</b>	20.0	21.9

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>13.7</b>	12.9	13.7
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>1.14</b>	0.83	0.63
Base Number (BN)	mg KOH/g	ASTM D2896	5.3	<b>4.11</b>	3.58	3.86











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.5	13.4	13.3

## GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
 Sample No. : WC0775335 Received : 04 Oct 2023  
 Lab Number : 05969088 Diagnosed : 06 Oct 2023  
 Unique Number : 10675639 Diagnostician : Jonathan Hester  
 Test Package : MOB 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**EDL NA Recips-Honeybrook**  
 Honey Brook Powerstation, 481 S. Churchtown Road  
 Narvon, PA  
 US 17555-9574  
 Contact: Christian Adames  
 Christian.Adames@edlenergy.com

T:  
F: