




COOLANT REPORT

Sample Rating Trend

NORMAL



Area
COLORADO/443/EG - SKID STEER
 Machine Id
53.134L [COLORADO^443^EG - SKID STEER]
 Component
Coolant
 Fluid
EXTENDED LIFE COOLANT (--- GAL)



DIAGNOSIS

Recommendation

The fluid is suitable for further service. No corrective action is recommended at this time.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Carboxylate test failed. Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0859570	WC0766174	WC0718093
Sample Date	Client Info		05 Oct 2023	01 Mar 2023	15 Sep 2022
Machine Age	hrs	Client Info	6075	5652	5278
Oil Age	hrs	Client Info	6075	5652	5278
Oil Changed	Client Info		Not Chngd	Not Chngd	Not Chngd
Sample Status			NORMAL	ABNORMAL	NORMAL

PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298		1.065	1.065	1.069
pH	Scale 0-14 ASTM D1287		10.2	10.8	8.25
Nitrites	ppm AP-053:2009		448	488	224
Reserve Alkalinity	Scale 0-20 *ASTM D1121		---	---	---
Percentage Glycol	% ASTM D3321		48.6	48.4	51.4
Freezing Point	°F ASTM D3321		-31	-31	-38
Total Dissolved Solids			475.5	677.0	359.5
Carboxylate			fail	fail	pass

CORROSION INHIBITORS

	method	limit/base	current	history1	history2
Silicon	ppm ASTM D6130		<1	25	10
Phosphorus	ppm ASTM D6130		120	0	0
Boron	ppm ASTM D6130		<1	31	104
Molybdenum	ppm ASTM D6130		921	1200	233

CORROSION

	method	limit/base	current	history1	history2
Iron	ppm ASTM D6130	>15	0	0	0
Aluminum	ppm ASTM D6130	>10	5	▲ 12	0
Copper	ppm ASTM D6130	>10	3	<1	0
Lead	ppm ASTM D6130	>10	0	<1	0
Tin	ppm ASTM D6130	>10	0	<1	0
Zinc	ppm ASTM D6130		0	1	0

CONTAMINANTS

	method	limit/base	current	history1	history2
Chlorine	ppm ASTM D6130		3	29	15

CARRIER SALTS


	method	limit/base	current	history1	history2
Sodium	ppm ASTM D6130		4454	7025	3154
Potassium	ppm ASTM D6130		1481	1478	852







SCALE POTENTIAL

	method	limit/base	current	history1	history2
Calcium	ppm ASTM D6130		<1	0	0
Magnesium	ppm ASTM D6130		<1	0	0









COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual		Red	Orange	Yellow
Coolant Appearance	*Visual	Clear	normal	normal	normal
Color					
Bottom					

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0859570 Received : 12 Oct 2023
 Lab Number : 05977886 Diagnosed : 18 Oct 2023
 Unique Number : 10695181 Diagnostician : Jonathan Hester
 Test Package : COOL- (Additional Tests: COOL, ICP)

SHERWOOD CONSTRUCTION CO INC
 3219 WEST MAY ST
 WICHITA, KS
 US 67213
 Contact: DOUG KING
 doug.king@sherwood.net
 T: (316)617-3161
 F: x:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)