



# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**Bernardsville**  
 Machine Id  
**MACK 1312**  
 Component  
**Diesel Engine**  
 Fluid  
**GIBRALTAR 15W/40 SUPER S-3 LX (11 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0830895</b>	---	---
Sample Date	Client Info		<b>28 Sep 2023</b>	---	---
Machine Age	hrs	Client Info	<b>35442</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>Not Chngd</b>	---	---
Sample Status			<b>NORMAL</b>	---	---

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>3.0	<b>&lt;1.0</b>	---	---
Glycol	WC Method		<b>NEG</b>	---	---

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >120	<b>38</b>	---	---
Chromium	ppm	ASTM D5185m >20	<b>1</b>	---	---
Nickel	ppm	ASTM D5185m >5	<b>&lt;1</b>	---	---
Titanium	ppm	ASTM D5185m >2	<b>&lt;1</b>	---	---
Silver	ppm	ASTM D5185m >2	<b>0</b>	---	---
Aluminum	ppm	ASTM D5185m >20	<b>3</b>	---	---
Lead	ppm	ASTM D5185m >40	<b>4</b>	---	---
Copper	ppm	ASTM D5185m >330	<b>2</b>	---	---
Tin	ppm	ASTM D5185m >15	<b>&lt;1</b>	---	---
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Cadmium	ppm	ASTM D5185m	<b>0</b>	---	---

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	<b>10</b>	---	---
Barium	ppm	ASTM D5185m	<b>12</b>	---	---
Molybdenum	ppm	ASTM D5185m 66	<b>61</b>	---	---
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Magnesium	ppm	ASTM D5185m 1000	<b>805</b>	---	---
Calcium	ppm	ASTM D5185m 1050	<b>1197</b>	---	---
Phosphorus	ppm	ASTM D5185m 1150	<b>990</b>	---	---
Zinc	ppm	ASTM D5185m 1270	<b>1208</b>	---	---
Sulfur	ppm	ASTM D5185m	<b>3077</b>	---	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>6</b>	---	---
Sodium	ppm	ASTM D5185m	<b>2</b>	---	---
Potassium	ppm	ASTM D5185m >20	<b>5</b>	---	---

## INFRA-RED


	method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844 >4	<b>1.6</b>	---	---
Nitration	Abs/cm	*ASTM D7624 >20	<b>9.0</b>	---	---
Sulfation	Abs/.1mm	*ASTM D7415 >30	<b>20.4</b>	---	---

## FLUID DEGRADATION


	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414 >25	<b>14.3</b>	---	---
Base Number (BN)	mg KOH/g	ASTM D2896 10.1	<b>8.0</b>	---	---



# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.2	NEG	---
Free Water	scalar	*Visual		NEG	---



FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	15.5	13.4	---

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0830895      **Received** : 13 Oct 2023  
**Lab Number** : 05978687      **Diagnosed** : 16 Oct 2023  
**Unique Number** : 10695982      **Diagnostician** : Wes Davis  
**Test Package** : FLEET

**INTERSTATE WASTE-BERNARDSVILLE**  
 33 OLD QUARRY ROAD  
 BERNARDSVILLE, NJ  
 US 07924  
 Contact: Pablo Chardon  
 PChardon@interstatewaste.com  
 T:  
 F:

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)