

PROBLEM SUMMARY

Sample Rating Trend

ISO


7664185 (S/N 3198)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status		AB	NORMAL	NORMAL	ABNORMAL				
Particles >6µm	ASTM D7647 >	>1300	3589	1194	▲ 3882				
Particles >14μm	ASTM D7647 >	>80	325	24	<u>224</u>				
Particles >21µm	ASTM D7647 >	>20	79	6	4 7				
Oil Cleanliness	ISO 4406 (c) >	>/17/13 🔺 🕻	21/19/16	19/17/12	<u>\</u> 21/19/15				

Customer Id: DIAFRECA Sample No.: KC122818 Lab Number: 05978945 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

18 Apr 2023 Diag: Don Baldridge

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



18 May 2022 Diag: Doug Bogart

150



No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



18 Jan 2022 Diag: Doug Bogart

ISO



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

7664185 (S/N 3198)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)





DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jan202	2 May2022	Apr2023 0	ct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC122818	KC100961	KC103741
Sample Date		Client Info		05 Oct 2023	18 Apr 2023	18 May 2022
Machine Age	hrs	Client Info		16631	15631	10109
Oil Age	hrs	Client Info		0	3000	3000
Oil Changed		Client Info		N/A	Changed	Changed
Sample Status				ABNORMAL	NORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	2
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	<1	<1
Copper	ppm	ASTM D5185m	>50	9	10	7
Tin	ppm	ASTM D5185m	>10	0	0	<1
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	90	0	0	56
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	4	2	69
Calcium	ppm	ASTM D5185m	0	2	0	1
Phosphorus	ppm	ASTM D5185m	0	<1	0	3
Zinc	ppm	ASTM D5185m	0	0	0	3
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	<1
Sodium	ppm	ASTM D5185m		3	1	10
Potassium	ppm	ASTM D5185m	>20	0	3	3
Water	%	ASTM D6304	>0.05	0.004	0.005	0.021
ppm Water	ppm	ASTM D6304	>500	45.8	55.0	218.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		10249	2731	19233
Particles >6µm		ASTM D7647	>1300	4 3589	1194	▲ 3882
Particles >14µm		ASTM D7647	>80	325	24	<u>^</u> 224
Particles >21µm		ASTM D7647	>20	<u>^</u> 79	6	▲ 47
Particles >38µm		ASTM D7647	>4	4	1	3
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/16	19/17/12	<u>^</u> 21/19/15
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.33	0.30	0.38



OIL ANALYSIS REPORT







Certificate L2367

Lab Number **Unique Number**

: 05978945 : 10696240 Test Package : IND 2

Diagnosed

: 17 Oct 2023

Diagnostician : Don Baldridge

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FREMONT, CA US 94539

Contact: D MILLER

d.miller@diamondfoundry.com

T: F:

Contact/Location: D MILLER - DIAFRECA