


COMPRESSORS

KAESER AS 20 5831886 (S/N 1192)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

PROBLEMATIC TEST RESULTS

FROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL				
Aluminum	ppm	ASTM D5185m	>10	<u> </u>				
Particles >6µm		ASTM D7647	>1300	43550				
Particles >14µm		ASTM D7647	>80	<u> </u>				
Particles >21µm		ASTM D7647	>20	<mark>/</mark> 396				
Particles >38µm		ASTM D7647	>4	<u> </u>				
Particles >71µm		ASTM D7647	>3	<u> </u>				
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u> </u>				
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	A 1.39				
Debris	scalar	*Visual	NONE	A MODER				
Visc @ 40°C	cSt	ASTM D445	45	A 87.55				

Sample Rating Trend

DEGRADATION

Customer Id: SABSALCA Sample No.: KCPA006142 Lab Number: 05978946 Test Package: IND 2




To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 <u>customerservice@wearcheck.com</u>

RECOMMENDED	ACTIONS			
Action	Status	Date	Done By	Description
Change Fluid			?	We recommend that you drain the oil from the component if this has not already been done.
Check For Overheating			?	We advise that you check for a possible overheat condition.

HISTORICAL DIAGNOSIS



Sample Rating Trend

DEGRADATION



KAESER AS 20 5831886 (S/N 1192)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for a possible overheat condition. We recommend that you drain the oil from the component if this has not already been done. The filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

🔺 Wear

The aluminum level is abnormal. All other component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil. Moderate concentration of visible dirt/debris present in the oil.


Fluid Condition


The oil viscosity is higher than normal. The AN level is at the top-end of the recommended limit.


				Oct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA006142		
Sample Date		Client Info		02 Oct 2023		
Machine Age	hrs	Client Info		40548		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ABNORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	16		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m	>3	0		
Titanium	ppm	ASTM D5185m	>3	0		
Silver	ppm	ASTM D5185m	>2	0		
Aluminum	ppm	ASTM D5185m	>10	<u> </u>		
Lead	ppm	ASTM D5185m	>10	0		
Copper	ppm	ASTM D5185m	>50	21		
Tin	ppm	ASTM D5185m	>10	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	5		
Barium	ppm	ASTM D5185m	90	0		
Molybdenum	ppm	ASTM D5185m	0	0		
Manganese	ppm	ASTM D5185m	0	۰ <1		
Magnesium	ppm	ASTM D5185m	100	1		
Calcium	ppm	ASTM D5185m	0	3		
		ASTM D5185m	0	62		
Phosphorus Zinc	ppm		0	19		
Sulfur	ppm	ASTM D5185m		-		
	ppm	ASTM D5185m	23500	759		
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	6		
Sodium	ppm	ASTM D5185m		10		
Potassium	ppm	ASTM D5185m	>20	2		
Water	%	ASTM D6304		0.048		
ppm Water	ppm	ASTM D6304	>500	485.6		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		113680		
Particles >6µm		ASTM D7647	>1300	<u> </u>		
Particles >14µm		ASTM D7647	>80	<u> </u>		
Particles >21µm		ASTM D7647	>20	<mark>/</mark> 396		
Particles >38µm		ASTM D7647	>4	<u> </u>		
Particles >71µm		ASTM D7647	>3	<u> </u>		
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 24/23/18		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	1.39		





Built for a lifetime











Certificate L2367