

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Machine Id WC-9817-0103-5 Chiller #3

Component Chiller

YORK TYPE K (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.


Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM		method	limit/base	current	history1	history2
			mmbasc			, i i i i i i i i i i i i i i i i i i i
Sample Number		Client Info		WC0836517	WC0784782	
Sample Date		Client Info		12 Oct 2023	03 May 2023	
Machine Age	hrs	Client Info		0	98816	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	0	
Chromium	ppm	ASTM D5185m	>2	0	0	
Nickel	ppm	ASTM D5185m		0	0	
Titanium	ppm	ASTM D5185m		0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>3	0	6	
Lead		ASTM D5185m	>2	0	0	
	ppm					
Copper	ppm	ASTM D5185m	>8	8	5	
Tin	ppm	ASTM D5185m	>4	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m		0	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		<1	0	
Magnesium	ppm	ASTM D5185m		0	2	
Calcium	ppm	ASTM D5185m		1	0	
Phosphorus	ppm	ASTM D5185m		<1	0	
Zinc	ppm	ASTM D5185m		0	0	
Sulfur	ppm	ASTM D5185m		2	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	9	8	
Sodium	ppm	ASTM D5185m		<1	0	
Potassium	ppm	ASTM D5185m	>20	0	1	
Water	%	ASTM D6304		0.033	0.045	
		ASTM D6304				
ppm Water	ppm			330.8	457.2	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	630	494	
Particles >6µm		ASTM D7647	>2500	156	147	
Particles >14µm		ASTM D7647	>320	14	14	
Particles >21µm		ASTM D7647	>80	3	3	
Particles >38µm		ASTM D7647	>20	0	0	
Particles >71µm		ASTM D7647	>4	0	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	16/14/11	16/14/11	
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.012	0.016	
(-)	0 - 0					




OIL ANALYSIS REPORT









 Certificate L2367
 Test Package
 : PLANT

 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 *

 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Diagnostician

: Doug Bogart

Annapolis Junction, MD US 20701 Contact: Susan Nord susan.nord@chugachgov.com T: (301)688-6363 6:2012) F: (443)479-5666

Contact/Location: Susan Nord - CHUANN