




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Area  
**[W119970]**  
 Machine Id  
**KATOLIGHT CAPITAL ASSOCIATE**  
 Component  
**Diesel Engine**  
 Fluid  
 **DIESEL ENGINE OIL SAE 5W40 (3 GAL)**

## DIAGNOSIS

### Recommendation

Resample at the next service interval to monitor.

### Wear

Metal levels are typical for a new component breaking in.

### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0753122</b>	WC0566997	WCM1396531
Sample Date	Client Info			<b>04 Oct 2023</b>	24 Sep 2021	14 Jun 2019
Machine Age	hrs	Client Info		<b>162</b>	143	112
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	Changed
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Fuel	WC Method	>2.1		<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method			<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>51	<b>0</b>	2	3
Chromium	ppm	ASTM D5185m	>11	<b>0</b>	<1	<1
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m		<b>&lt;1</b>	1	1
Silver	ppm	ASTM D5185m	>3	<b>&lt;1</b>	<1	0
Aluminum	ppm	ASTM D5185m	>31	<b>2</b>	<1	2
Lead	ppm	ASTM D5185m	>26	<b>0</b>	<1	<1
Copper	ppm	ASTM D5185m	>26	<b>&lt;1</b>	<1	2
Tin	ppm	ASTM D5185m	>4	<b>&lt;1</b>	0	0
Antimony	ppm	ASTM D5185m		<b>---</b>	0	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	<1	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	250	<b>83</b>	104	17
Barium	ppm	ASTM D5185m	10	<b>0</b>	0	2
Molybdenum	ppm	ASTM D5185m	100	<b>66</b>	<1	9
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m	450	<b>178</b>	721	12
Calcium	ppm	ASTM D5185m	3000	<b>1938</b>	1335	2275
Phosphorus	ppm	ASTM D5185m	1150	<b>934</b>	1034	937
Zinc	ppm	ASTM D5185m	1350	<b>1180</b>	1210	1065
Sulfur	ppm	ASTM D5185m	4250	<b>3679</b>	3550	3258



CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>22	<b>13</b>	11	37
Sodium	ppm	ASTM D5185m	>44	<b>2</b>	1	3
Potassium	ppm	ASTM D5185m	>20	<b>1</b>	3	7

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844	>3	<b>0</b>	0	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>7.1</b>	6.2	4.4
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>17.0</b>	19.2	17.2

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>12.8</b>	12.8	12.9
Base Number (BN)	mg KOH/g	ASTM D2896	8.5	<b>6.9</b>	---	---











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.21	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.4	14.5	14.8

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0753122 **Received** : 16 Oct 2023  
**Lab Number** : 05979290 **Diagnosed** : 17 Oct 2023  
**Unique Number** : 10696585 **Diagnostician** : Wes Davis  
**Test Package** : MOB 1 ( Additional Tests: TBN )

**NATIONAL POWER CORP**  
 4541 PRESLYN DR  
 RALEIGH, NC  
 US 27616  
 Contact: ANDREW RANDALL  
 andrew.randall@natpow.com  
 T: (919)790-1672  
 F: (919)790-9714

Certificate L2367  
 To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)