

PROBLEM SUMMARY



Machine Id SL 1B Component Hydraulic System Fluid ROYAL PURPLE SYNDRAULIC 68 (100 GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

PROBLEMATIC TEST RESULTS Sample Status SEVERE ATTENTION ABNORMAL Particles >4µm ASTM D7647 >5000 85795 ▲ 5427 ▲ 29964 Particles >6µm ASTM D7647 >1300 26264 **1497** ▲ 8049 Particles >14µm ASTM D7647 >160 2224 159 509 Particles >21µm ASTM D7647 >40 650 49 **6** Particles >38µm 2 **1**1 ASTM D7647 >10 **45 Oil Cleanliness** ISO 4406 (c) >19/17/14 24/22/18 ▲ 20/18/14 ▲ 22/20/16

Customer Id: JOHPUL Sample No.: RP0018150 Lab Number: 05979602 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

| RECONNENDED | 40110113 | | | |
|-------------------|----------|------|---------|--|
| Action | Status | Date | Done By | Description |
| Change Filter | | | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |
| Resample | | | ? | Resample in 30-45 days to monitor this situation. |
| Check Breathers | | | ? | The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. |
| Check Dirt Access | | | ? | We advise that you check all areas where contaminants can enter the system. |
| Filter Fluid | | | ? | We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. |

HISTORICAL DIAGNOSIS



We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



23 Mar 2023 Diag: Doug Bogart

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

09 Jan 2023 Diag: Jonathan Hester

ISO

We recommend you service the filters on this component. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report





OIL ANALYSIS REPORT



ISO

Machine Id SL 1B Component Hydraulic System Fluid ROYAL PURPLE SYNDRAULIC 68 (100 GAL)

DIAGNOSIS

Recommendation

We advise that you check all areas where contaminants can enter the system. We advise that you perform a filter service, and use off-line filtration to improve the cleanliness of the system fluid. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. Resample in 30-45 days to monitor this situation.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates (2 to 100 microns in size) present in the oil. The water content is negligible.

Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.

| L) | | ay2014 Jul201 | 5 Jul2018 Apr2019 Ja | m2020 Sep2020 Jun2021 Oct202 | 2 Jul2023 | |
|------------------|----------|---------------|----------------------|------------------------------|-------------|---------------|
| SAMPLE INFORM | IATION | method | limit/base | current | history1 | history2 |
| Sample Number | | Client Info | | RP0018150 | RP0018348 | RP0028401 |
| Sample Date | | Client Info | | 21 Sep 2023 | 09 Jul 2023 | 23 Mar 2023 |
| Machine Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Age | hrs | Client Info | | 0 | 0 | 0 |
| Oil Changed | | Client Info | | N/A | N/A | N/A |
| Sample Status | | | | SEVERE | ATTENTION | ABNORMAL |
| WEAR METALS | | method | limit/base | current | history1 | history2 |
| Iron | ppm | ASTM D5185m | >20 | 2 | 1 | <1 |
| Chromium | ppm | ASTM D5185m | >20 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m | >20 | 0 | <1 | 0 |
| Titanium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Silver | ppm | ASTM D5185m | | 0 | <1 | 0 |
| Aluminum | ppm | ASTM D5185m | >20 | 0 | <1 | 0 |
| Lead | ppm | ASTM D5185m | >20 | 0 | <1 | 0 |
| Copper | ppm | ASTM D5185m | >20 | 5 | 3 | 2 |
| Tin | ppm | ASTM D5185m | >20 | 0 | 0 | 0 |
| Vanadium | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | | 0 | <1 | 0 |
| ADDITIVES | | method | limit/base | current | history1 | history2 |
| Boron | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m | | 0 | 1 | 0 |
| Molybdenum | ppm | ASTM D5185m | | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | | <1 | 0 | <1 |
| Magnesium | ppm | ASTM D5185m | | 0 | <1 | 1 |
| Calcium | ppm | ASTM D5185m | | 30 | 11 | 44 |
| Phosphorus | ppm | ASTM D5185m | | 321 | 320 | 333 |
| Zinc | ppm | ASTM D5185m | | 399 | 345 | 423 |
| CONTAMINANTS | | method | limit/base | current | history1 | history2 |
| Silicon | ppm | ASTM D5185m | >15 | <1 | <1 | <1 |
| Sodium | ppm | ASTM D5185m | | <1 | 0 | 0 |
| Potassium | ppm | ASTM D5185m | >20 | 0 | 0 | 0 |
| Water | % | ASTM D6304 | >0.05 | 0.008 | 0.013 | 0.011 |
| ppm Water | ppm | ASTM D6304 | >500 | 86.5 | 139.5 | 114.1 |
| FLUID CLEANLIN | ESS | method | limit/base | current | history1 | history2 |
| Particles >4µm | | ASTM D7647 | >5000 | e 85795 | ▲ 5427 | 2 9964 |
| Particles >6µm | | ASTM D7647 | >1300 | e 26264 | <u> </u> | ▲ 8049 |
| Particles >14µm | | ASTM D7647 | >160 | 2224 | 159 | ▲ 509 |
| Particles >21µm | | ASTM D7647 | >40 | 6 50 | 49 | ▲ 96 |
| Particles >38µm | | ASTM D7647 | >10 | 4 5 | 2 | ▲ 11 |
| Particles >71µm | | ASTM D7647 | >3 | 2 | 0 | 0 |
| Oil Cleanliness | | ISO 4406 (c) | >19/17/14 | 24/22/18 | 20/18/14 | 22/20/16 |
| FLUID DEGRADA | TION | method | limit/base | current | history1 | history2 |
| Acid Number (AN) | mg KOH/g | ASTM D8045 | | 0.45 | 0.35 | 0.42 |



1.20

OIL ANALYSIS REPORT







| VISUAL | | method | limit/base | current | history1 | history2 |
|--|------------|-------------------------------|----------------------------------|----------------------------|------------------------------|------------------------------|
| White Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE | LIGHT |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG | NEG |
| | | | | | | |
| FLUID PROPERT | IES | method | limit/base | current | history1 | history2 |
| FLUID PROPERT Visc @ 40°C | iES cSt | method ASTM D445 | limit/base 68.0 | current 68.0 | history1 73.3 | history2 68.0 |
| FLUID PROPERT Visc @ 40°C SAMPLE IMAGES | IES cSt | method ASTM D445 method | limit/base 68.0 limit/base | current 68.0 current | history1 73.3 history1 | history2 68.0 history2 |
| FLUID PROPERT Visc @ 40°C SAMPLE IMAGES Color | CSt | method ASTM D445 method | limit/base 68.0 limit/base | current 68.0 current | history1 73.3 history1 | history2 68.0 history2 |



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: JEREMY ROSE - JOHPUL

F: