


# **PROBLEM SUMMARY**

# KAESER CSD 75 5050670 (S/N 1036)

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



No relevant graphs to display

#### RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

PROBLEMATIC TEST RESULTS							
Sample Status				ABNORMAL	SEVERE	NORMAL	
Silt	scalar	*Visual	NONE	🔺 MODER	NONE	NONE	

Customer Id: POWMONKC Sample No.: KC124469 Lab Number: 05979614 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Jonathan Hester +1 919-379-4092 x4092 <u>jhester@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS						
Action	Status	Date	Done By			
Alert			?			

#### Description

We were unable to perform a particle count due to a high concentration of particles present in this sample.

### HISTORICAL DIAGNOSIS

#### 01 Mar 2023 Diag: Jonathan Hester



The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drainoff procedure for this component. We recommend an early resample in 500 hours to monitor this condition.All component wear rates are normal. There is a light concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### 08 Nov 2022 Diag: Angela Borella



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



# NORMAL



Resample at the next service interval to monitor.All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# Decemble at the pout convice interval to



# **OIL ANALYSIS REPORT**

# KAESER CSD 75 5050670 (S/N 1036)

**Compressor** Fluid

KAESER SIGMA (OEM) S-460 (--- GAL)

## DIAGNOSIS

### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

## Wear


All component wear rates are normal.

### Contamination

There is a moderate amount of visible silt present in the sample.

### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124469	KC105634	KC108269
Sample Date		Client Info		09 Aug 2023	01 Mar 2023	08 Nov 2022
Machine Age	hrs	Client Info		49775	4754	45508
Oil Age	hrs	Client Info		0	4754	3000
Oil Changed		Client Info		N/A	Not Changd	N/A
Sample Status				ABNORMAL	SEVERE	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	5	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	9	9	7
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	0	2	<1
Calcium	ppm	ASTM D5185m	2	0	<1	0
Phosphorus	ppm	ASTM D5185m		0	3	2
Zinc	ppm	ASTM D5185m		0	2	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	0	0
Sodium	ppm	ASTM D5185m	220	2	1	<1
Potassium	ppm	ASTM D5185m	>20	- <1	0	0
Water	%	ASTM D6304		0.007	▲ 0.151	0.009
ppm Water	ppm	ASTM D6304	>500	71.8	▲ 1510	90.7
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647				307
Particles >6µm		ASTM D7647	>1300			89
Particles >14µm		ASTM D7647	>80			7
Particles >21µm		ASTM D7647				1
Particles >38µm		ASTM D7647	>4			0
Particles >71µm		ASTM D7647				0
Oil Cleanliness		ISO 4406 (c)	>/17/13			15/14/10
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.36	0.37	0.37



# **OIL ANALYSIS REPORT**









VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	🔺 MODER	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	🔺 MODER	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%	NEG
Free Water	scalar	*Visual		NEG	• 10.0	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.1	44.4	44.3
SAMPLE IMAGES	S	method	limit/base	current	history1	history2

Color



Bottom





\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Certificate L2367

Contact/Location: ? ? - POWMONKC

F: