


KAESER COMPRESSORS Built for a lifetime."

KAESER 7365952

Component Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS Sample Status ABNORMAL ABNORMAL **ATTENTION** Particles >6µm ASTM D7647 >1300 **A** 7516 ▲ 2645 Particles >14µm ASTM D7647 >80 **60 A** 313 **A** 83 Particles >21µm 8 ASTM D7647 >20 177 77 **Oil Cleanliness** ISO 4406 (c) >--/17/13 **A** 22/20/17 ▲ 20/19/15 ▲ 20/18/14


Customer Id: AMAROSOH Sample No.: KC124468 Lab Number: 05979631 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 jhester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

23 May 2023 Diag: Angela Borella

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

04 Feb 2023 Diag: Don Baldridge

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

25 Oct 2022 Diag: Angela Borella

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of silt (particulates < 14 microns in size) present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



view report



OIL ANALYSIS REPORT

Machine Id KAESER 7365952 Component

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC124468	KC110678	KC105617
Sample Date		Client Info		16 Aug 2023	23 May 2023	04 Feb 2023
Machine Age	hrs	Client Info		12572	11558	1436
Oil Age	hrs	Client Info		0	4333	2998
Oil Changed		Client Info		N/A	Not Changd	Not Changd
Sample Status				ABNORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	1	0
Lead	ppm	ASTM D5185m	>10	0	0	<1
Copper	ppm	ASTM D5185m	>50	6	3	3
Tin	ppm	ASTM D5185m	>10	0	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	0	18	19
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	90	22	46	65
Calcium	ppm	ASTM D5185m	2	0	0	3
Phosphorus	ppm	ASTM D5185m		0	4	6
Zinc	ppm	ASTM D5185m		0	0	5
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	3
Sodium	ppm	ASTM D5185m		7	10	14
Potassium	ppm	ASTM D5185m	>20	1	3	8
Water	%	ASTM D6304	>0.05	0.018	0.019	0.006
ppm Water	ppm	ASTM D6304	>500	180.7	198.9	60.6
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		20425	6367	6814
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u> </u>	<u> </u>
Particles >14µm		ASTM D7647	>80	<u> </u>	A 313	<u> </u>
Particles >21µm		ASTM D7647		<u> </u>	<u>∧</u> 77	8
Particles >38µm		ASTM D7647	>4	3	1	0
Particles >71µm		ASTM D7647		1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 22/20/17	2 0/19/15	▲ 20/18/14
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.30	0.34	0.27



OIL ANALYSIS REPORT








47

3

40 - Abnorma


C/01/vol

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.3	43.9	42.0
SAMPLE IMAGES		method	limit/base	current	history1	history2



Bottom

Color



Contact/Location: Service Manager - AMAROSOH