

PROBLEM SUMMARY

Sample Rating Trend

WEAR





L7 A (S/N N/A)

Component Vacuum Pump

USPI VAC 100 (--- QTS)







RECOMMENDATION

We recommend you service the filters on this component. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS								
Sample Status				ABNORMAL	ABNORMAL	NORMAL		
Iron	ppm	ASTM D5185m	>20	<u> </u>	<u>^</u> 74	0		
Particles >4µm		ASTM D7647	>10000	<u> </u>	<u>205617</u>	630		
Particles >6µm		ASTM D7647	>2500	143667	141083	164		
Particles >14µm		ASTM D7647	>640	<u> </u>	<u>▲</u> 8643	13		
Particles >21µm		ASTM D7647	>160	1097	△ 395	3		
Oil Cleanliness		ISO 4406 (c)	>20/18/16	<u> 25/24/21</u>	25/24/20	16/15/11		

Customer Id: KRAKIRMO Sample No.: USPM31031 Lab Number: 05979664 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Doug Bogart +1 (800)237-1369 x4016 dougb@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Change Filter			?	We recommend you service the filters on this component.

HISTORICAL DIAGNOSIS

10 Jul 2023 Diag: Doug Bogart

WEAR



We recommend you service the filters on this component. Resample at the next service interval to monitor. The iron level is abnormal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



04 May 2023 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



05 Jan 2023 Diag: Doug Bogart

VIS DEBRIS




We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





OIL ANALYSIS REPORT

Sample Rating Trend



WEAR



Machine Id L7 A (S/N N/A) Component

Vacuum Pump

USPI VAC 100 (--- QTS)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

The iron level is abnormal.

Contamination

There is a high amount of particulates present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Dec2021	Mar2022 Sep2022	Jan2023 May2023 Jul2023	0ct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		USPM31031	USPM27751	USPM25379
Sample Date		Client Info		15 Oct 2023	10 Jul 2023	04 May 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	135	<u>^</u> 74	0
Chromium	ppm	ASTM D5185m	>20	<1	0	0
Nickel	ppm	ASTM D5185m	>20	0	0	0
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	<1	1	<1
Lead	ppm	ASTM D5185m	>20	0	0	0
Copper	ppm	ASTM D5185m	>20	<1	<1	0
Tin	ppm	ASTM D5185m	>20	<1	<1	0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		<1	<1	<1
Magnesium	ppm	ASTM D5185m	0	0	0	0
Calcium	ppm	ASTM D5185m	0	0	2	0
Phosphorus	ppm	ASTM D5185m	1800	1353	1466	1702
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	0	0	2	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	13	2	3
Sodium	ppm	ASTM D5185m	0.0	62	6	0
Potassium	ppm	ASTM D5185m	>20	25	8	<1
Water	%	ASTM D6304		0.054	0.048	0.073
ppm Water	ppm	ASTM D6304	>1000	543.8	481.7	739.2
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<u>^</u> 214957	<u>^</u> 205617	630
Particles >6µm		ASTM D7647	>2500	<u> </u>	<u>141083</u>	164
Particles >14μm		ASTM D7647	>640	<u> </u>	<u>▲</u> 8643	13
Particles >21µm		ASTM D7647	>160	<u> </u>	▲ 395	3
Particles >38µm		ASTM D7647	>40	7	2	0
Particles >71µm		ASTM D7647	>10	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/16	<u>25/24/21</u>	<u>△</u> 25/24/20	16/15/11
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.05	0.69	0.54	0.16



OIL ANALYSIS REPORT



* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F:

T: (660)627-1031