




# OIL ANALYSIS REPORT

Sample Rating Trend



**DIRT**



Machine Id  
**SJNM01BE**  
 Component  
**Biogas Engine**  
 Fluid  
**CHEVRON HDAX 6500 LFG GAS ENGINE OIL (--- GAL)**

## DIAGNOSIS

### Recommendation

The oil change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### Contamination

Elemental level of silicon (Si) above normal.

### Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0764363</b>	WC0764359	WC0764362
Sample Date	Client Info		<b>12 Oct 2023</b>	05 Oct 2023	28 Sep 2023
Machine Age	hrs	Client Info	<b>67432</b>	67265	67101
Oil Age	hrs	Client Info	<b>982</b>	815	651
Oil Changed	Client Info		<b>Changed</b>	Not Changd	Not Changd
Sample Status			<b>SEVERE</b>	SEVERE	NORMAL

## CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<b>&lt;1.0</b>	<1.0	<1.0
Glycol	WC Method		<b>NEG</b>	NEG	NEG

## WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	<b>8</b>	6	10
Chromium	ppm	ASTM D5185m	>4	<b>&lt;1</b>	<1	<1
Nickel	ppm	ASTM D5185m	>2	<b>&lt;1</b>	2	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	<1
Silver	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m	>6	<b>&lt;1</b>	0	<1
Lead	ppm	ASTM D5185m	>9	<b>6</b>	8	6
Copper	ppm	ASTM D5185m	>6	<b>3</b>	3	1
Tin	ppm	ASTM D5185m	>4	<b>3</b>	4	4
Vanadium	ppm	ASTM D5185m		<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<b>8</b>	10	16
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>8</b>	10	8
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	<1
Magnesium	ppm	ASTM D5185m		<b>14</b>	23	24
Calcium	ppm	ASTM D5185m		<b>1845</b>	1996	2015
Phosphorus	ppm	ASTM D5185m		<b>255</b>	308	328
Zinc	ppm	ASTM D5185m		<b>319</b>	410	400
Sulfur	ppm	ASTM D5185m		<b>1938</b>	2528	2301

## CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	<b>221</b>	223	171
Sodium	ppm	ASTM D5185m		<b>34</b>	41	31
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	4	1

## INFRA-RED





	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		<b>0.1</b>	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>20	<b>8.0</b>	8.0	7.5
Sulfation	Abs/.1mm	*ASTM D7415	>30	<b>23.8</b>	23.8	21.9

## FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	<b>18.9</b>	18.0	14.7
Acid Number (AN)	mg KOH/g	ASTM D8045	1.2	<b>1.49</b>	1.59	1.68
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	<b>4.67</b>	4.71	4.75











# OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	14.7	14.5	14.4

### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0764363 **Received** : 16 Oct 2023  
**Lab Number** : 05979898 **Diagnosed** : 18 Oct 2023  
**Unique Number** : 10697193 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2

**EDL NA Recips-South Jordan**  
 South Jordan Powerstation, 10473 S. Bacchus Hwy.  
 South Jordan, UT  
 US 84095  
 Contact: Aaron Klein  
 aaron.klein@edlenergy.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)