




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
LGS00180

Component
Middle Biogas Engine

Fluid
CITGO PACEMAKER GAS ENGINE LFG LA 40 (--- GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0803444	WC0803443	WC0803440
Sample Date	Client Info		02 Oct 2023	19 Sep 2023	17 Sep 2023
Machine Age	hrs	Client Info	58951	58570	58404
Oil Age	hrs	Client Info	142	265	99
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	NORMAL	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>45	0	4	6
Chromium	ppm	ASTM D5185m	>2	0	<1	<1
Nickel	ppm	ASTM D5185m	>2	0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>5	0	0	0
Aluminum	ppm	ASTM D5185m	>10	1	4	3
Lead	ppm	ASTM D5185m	>5	0	<1	<1
Copper	ppm	ASTM D5185m	>14	0	2	<1
Tin	ppm	ASTM D5185m	>13	2	3	1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		<1	0	0
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	3	3
Manganese	ppm	ASTM D5185m		0	1	0
Magnesium	ppm	ASTM D5185m		25	30	28
Calcium	ppm	ASTM D5185m		1434	1474	1412
Phosphorus	ppm	ASTM D5185m		266	301	288
Zinc	ppm	ASTM D5185m		362	349	371
Sulfur	ppm	ASTM D5185m		3097	3499	3346

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>200	103	141	85
Sodium	ppm	ASTM D5185m		<1	3	<1
Potassium	ppm	ASTM D5185m	>20	0	0	<1

INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0	0	0
Nitration	Abs/cm	*ASTM D7624	>20	3.7	3.9	4.1
Sulfation	Abs/.1mm	*ASTM D7415	>30	16.8	17.3	16.0

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414	>25	7.5	8.2	7.4
Acid Number (AN)	mg KOH/g	ASTM D8045	1.16	0.93	0.88	0.73
Base Number (BN)	mg KOH/g	ASTM D2896	5	3.42	3.48	3.44











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.5	13.0	13.1	12.9

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0803444
 Lab Number : 05979912
 Unique Number : 10697207
 Test Package : MOB 2

Received : 16 Oct 2023
 Diagnosed : 17 Oct 2023
 Diagnostician : Sean Felton

BLACK OAK
 5054 HWY HH
 HARTVILLE, MO
 US 65667

Contact: CHIP MATHEWS
 chip.matthews@cubedistrictenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
 F: