




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**BULK SHELL MYSELLA S5**  
 Component  
**New (Unused) Oil**  
 Fluid  
**SHELL MYSELLA S5 S (--- GAL)**

## DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0775432</b>	WC0775334	WC0775333
Sample Date	Client Info			<b>12 Oct 2023</b>	15 Sep 2023	28 Jul 2023
Machine Age	hrs	Client Info		<b>0</b>	0	0
Oil Age	hrs	Client Info		<b>0</b>	0	0
Oil Changed	Client Info			<b>N/A</b>	N/A	Not Changd
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>5	<b>0</b>	<1	<1
Chromium	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Titanium	ppm	ASTM D5185m		<b>0</b>	<1	0
Silver	ppm	ASTM D5185m	>5	<b>&lt;1</b>	0	2
Aluminum	ppm	ASTM D5185m	>5	<b>2</b>	2	1
Lead	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>5	<b>0</b>	<1	<1
Tin	ppm	ASTM D5185m	>5	<b>0</b>	<1	0
Vanadium	ppm	ASTM D5185m		<b>0</b>	<1	<1
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	<1

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>0</b>	4	2
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>2</b>	6	<1
Manganese	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m		<b>6</b>	15	11
Calcium	ppm	ASTM D5185m		<b>1372</b>	1593	1310
Phosphorus	ppm	ASTM D5185m	300	<b>333</b>	333	270
Zinc	ppm	ASTM D5185m		<b>403</b>	377	321
Sulfur	ppm	ASTM D5185m		<b>2994</b>	3661	2996





CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<b>6</b>	7	6
Sodium	ppm	ASTM D5185m		<b>0</b>	1	<1
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	1	0

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>---</b>	---	---
Nitration	Abs/cm	*ASTM D7624		<b>---</b>	---	---
Sulfation	Abs/.1mm	*ASTM D7415		<b>---</b>	---	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414		<b>---</b>	---	---
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.648</b>	0.611	0.35
Base Number (BN)	mg KOH/g	ASTM D2896	5.3	<b>5.45</b>	4.59	4.77




# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	NEG	NEG	NEG
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	125	125.8	121.0	124.8
Visc @ 100°C	cSt	ASTM D445	13.5	13.6	13.26	13.44
Viscosity Index (VI)	Scale	ASTM D2270	103	103	104	102

### SAMPLE IMAGES



### GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0775432 **Received** : 16 Oct 2023  
**Lab Number** : 05980079 **Diagnosed** : 19 Oct 2023  
**Unique Number** : 10697374 **Diagnostician** : Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: FT-IR, KV100, PrtCount, TBN, VI )

**EDL NA Recips-Honeybrook**  
 Honey Brook Powerstation, 481 S. Churchtown Road  
 Narvon, PA  
 US 17555-9574  
 Contact: Christian Adames  
 Christian.Adames@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)