




COOLANT REPORT

Sample Rating Trend

NORMAL



Machine Id
Coopersville CAT 7 CPVM07BE
 Component
Jacket Water Coolant
 Fluid
CHEVRON HEAVY DUTY PF COOLANT (--- GAL)



DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0819479	WC0765307	WC0508683
Sample Date	Client Info		11 Oct 2023	29 Mar 2023	09 Mar 2022
Machine Age	hrs	Client Info	103783	66590	102829
Oil Age	hrs	Client Info	0	448	8760
Oil Changed	Client Info		Not Chngd	Changed	Not Chngd
Sample Status			NORMAL	NORMAL	NORMAL

PHYSICAL TEST RESULTS

	method	limit/base	current	history1	history2
Specific Gravity	*ASTM D1298		1.067	1.068	1.068
pH	Scale 0-14 ASTM D1287	10.5	8.32	8.34	7.69
Nitrites	ppm AP-053:2009	>800	976	1124	636
Reserve Alkalinity	Scale 0-20 *ASTM D1121		---	---	---
Percentage Glycol	% ASTM D3321	50	49.9	50.3	50.4
Freezing Point	°F ASTM D3321	-37	-33	-35	-35
Total Dissolved Solids			232.0	226.0	255.5
Carboxylate			n/a	n/a	n/a

CORROSION INHIBITORS

	method	limit/base	current	history1	history2
Silicon	ppm ASTM D6130	1000	34	118	105
Phosphorus	ppm ASTM D6130	0	5	24	6
Boron	ppm ASTM D6130		276	502	663
Molybdenum	ppm ASTM D6130		120	131	426

CORROSION

	method	limit/base	current	history1	history2
Iron	ppm ASTM D6130	>15	0	2	<1
Aluminum	ppm ASTM D6130	>10	<1	<1	<1
Copper	ppm ASTM D6130	>10	0	2	4
Lead	ppm ASTM D6130	>10	0	<1	0
Tin	ppm ASTM D6130	>10	0	2	1
Zinc	ppm ASTM D6130		0	2	2

CONTAMINANTS

	method	limit/base	current	history1	history2
Chlorine	ppm ASTM D6130		0	23	885

CARRIER SALTS


	method	limit/base	current	history1	history2
Sodium	ppm ASTM D6130		1747	2941	1915
Potassium	ppm ASTM D6130		29	129	90

SCALE POTENTIAL

	method	limit/base	current	history1	history2
Calcium	ppm ASTM D6130		<1	4	1
Magnesium	ppm ASTM D6130		<1	<1	<1









COOLANT REPORT



VISUAL	method	limit/base	current	history1	history2
Coolant Color	*Visual	Grn/Prpl	Pink	Pink	Pink
Coolant Appearance	*Visual	Clear	normal	normal	normal
Color					
Bottom					

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0819479 **Received** : 16 Oct 2023
Lab Number : 05980098 **Diagnosed** : 19 Oct 2023
Unique Number : 10697393 **Diagnostician** : Jonathan Hester
Test Package : COOL- (Additional Tests: COOL, ICP)

EDL NA Recips-Coopersville
 Coopersville Powerstation, 15362 68th Avenue
 Coopersville, MI
 US 49404
 Contact: Daniel Young
 daniel.young@edlenergy.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)