




### Machine Id 6383627 (S/N 1075) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

### COMPONENT CONDITION SUMMARY



### RECOMMENDATION

No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS						
Sample Status		ATTENTIC	N NORMAL	ATTENTION		
Particles >6µm	ASTM D7647 :	>1300 🔺 1601	228	<b>1</b> 772		
Oil Cleanliness	ISO 4406 (c)	>/17/13 🔺 20/18/13	<b>B</b> 17/15/11	<b>2</b> 0/18/14		


Customer Id: SILSUMCA Sample No.: KCPA007751 Lab Number: 05980389 Test Package: IND 2



To manage this report scan the QR code

*To discuss the diagnosis or test data:* Doug Bogart +1 (800)237-1369 x4016 <u>dougb@wearcheckusa.com</u>

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 01 Jun 2023 Diag: Don Baldridge



Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


#### 07 Feb 2023 Diag: Don Baldridge



Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.









Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.







### **OIL ANALYSIS REPORT**

SAMPLE INFORMATION method

# Sample Rating Trend ISO

current

history1

history2

Machine Id 6383627 (S/N 1075) Component

Compressor Fluid KAESER SIGMA (OEM) M-460 (--- GAL)

### DIAGNOSIS

### A Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

### Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		methou	IIIIII/Dase	Current	TISTOLAL	TISTOLAS
Sample Number		Client Info		KCPA007751	KCPA003420	KCP55373
Sample Date		Client Info		07 Oct 2023	01 Jun 2023	07 Feb 2023
Machine Age	hrs	Client Info		31038	28017	29972
Oil Age	hrs	Client Info		0	0	7000
Oil Changed		Client Info		N/A	N/A	Changed
Sample Status				ATTENTION	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	<1	0	1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	3	2
Tin	ppm	ASTM D5185m	>10	<1	0	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	20	0	24
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m	100	50	35	61
Calcium	ppm	ASTM D5185m	0	2	0	<1
Phosphorus	ppm	ASTM D5185m	0	<1	<1	4
Zinc	ppm	ASTM D5185m	0	5	0	1
Sulfur	ppm	ASTM D5185m	23500	21962	25007	22042
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	5	<1	<1
Sodium	ppm	ASTM D5185m		6	2	12
Potassium	ppm	ASTM D5185m		2	<1	<1
Water	%	ASTM D6304	>0.05	0.014	0.012	0.015
ppm Water	ppm	ASTM D6304	>500	148.9	126.8	158.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		6615	890	5880
Particles >6µm		ASTM D7647	>1300	🔺 1601	228	<mark>▲</mark> 1772
Particles >14µm		ASTM D7647	>80	55	12	<u> </u>
Particles >21µm		ASTM D7647	>20	9	3	18
Particles >38µm		ASTM D7647	>4	0	0	0
Particles >71µm		ASTM D7647	>3	0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>A</b> 20/18/13	17/15/11	▲ 20/18/14
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.37	0.40	0.38


limit/base



## **OIL ANALYSIS REPORT**








VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	<b>FIES</b>	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	49.3	50.3	49.5
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color						





Bottom

