




PROBLEM SUMMARY

Sample Rating Trend




ISO



Machine Id
KAESER AIR CENTER SK 20 5344990 (S/N 1659)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)

COMPONENT CONDITION SUMMARY

▲ Particle Trend



RECOMMENDATION

No corrective action is recommended at this time.
 Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS

| Sample Status | | ATTENTION | NORMAL | NORMAL |
|-----------------|------------------------|------------|----------|--------|
| Particles >6µm | ASTM D7647 >1300 | ▲ 1470 | 504 | 584 |
| Oil Cleanliness | ISO 4406 (c) >--/17/13 | ▲ 20/18/13 | 19/16/11 | 16/11 |

Customer Id: MURSUW
 Sample No.: KCPA000689
 Lab Number: 05980406
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Don Baldrige +1
don.b505@comcast.net

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

There are no recommended actions for this sample.

HISTORICAL DIAGNOSIS

31 Aug 2022 Diag: Don Baldrige

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



05 Nov 2021 Diag: Jonathan Hester

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

view report



05 Oct 2020 Diag: Angela Borella

NORMAL



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. The amount and size of particulates present in the system are acceptable. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


view report





OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id
KAESER AIR CENTER SK 20 5344990 (S/N 1659)

Component
Compressor

Fluid
KAESER SIGMA (OEM) M-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

| | method | limit/base | current | history1 | history2 |
|---------------|-------------|-------------|--------------------|-------------|-------------|
| Sample Number | Client Info | | KCPA000689 | KCP49336 | KCP39782 |
| Sample Date | Client Info | | 29 Sep 2023 | 31 Aug 2022 | 05 Nov 2021 |
| Machine Age | hrs | Client Info | 25210 | 21004 | 17142 |
| Oil Age | hrs | Client Info | 0 | 3861 | 3000 |
| Oil Changed | Client Info | | N/A | Changed | Changed |
| Sample Status | | | ATTENTION | NORMAL | NORMAL |

WEAR METALS

| | method | limit/base | current | history1 | history2 |
|----------|--------|-----------------|--------------|----------|----------|
| Iron | ppm | ASTM D5185m >50 | 0 | <1 | <1 |
| Chromium | ppm | ASTM D5185m >10 | 0 | 0 | 0 |
| Nickel | ppm | ASTM D5185m >3 | <1 | 0 | 0 |
| Titanium | ppm | ASTM D5185m >3 | 0 | 0 | 0 |
| Silver | ppm | ASTM D5185m >2 | <1 | 0 | <1 |
| Aluminum | ppm | ASTM D5185m >10 | <1 | <1 | 0 |
| Lead | ppm | ASTM D5185m >10 | 0 | 0 | <1 |
| Copper | ppm | ASTM D5185m >50 | <1 | 1 | 2 |
| Tin | ppm | ASTM D5185m >10 | <1 | 0 | 0 |
| Antimony | ppm | ASTM D5185m | --- | --- | 0 |
| Vanadium | ppm | ASTM D5185m | 0 | 0 | 0 |
| Cadmium | ppm | ASTM D5185m | 0 | 0 | 0 |

ADDITIVES

| | method | limit/base | current | history1 | history2 |
|------------|--------|-------------------|--------------|----------|----------|
| Boron | ppm | ASTM D5185m 0 | 0 | 0 | 0 |
| Barium | ppm | ASTM D5185m 90 | 11 | 22 | <1 |
| Molybdenum | ppm | ASTM D5185m 0 | 0 | 0 | 0 |
| Manganese | ppm | ASTM D5185m | 0 | 0 | 0 |
| Magnesium | ppm | ASTM D5185m 100 | 83 | 74 | 71 |
| Calcium | ppm | ASTM D5185m 0 | 2 | <1 | <1 |
| Phosphorus | ppm | ASTM D5185m 0 | <1 | 1 | 2 |
| Zinc | ppm | ASTM D5185m 0 | 5 | 2 | 0 |
| Sulfur | ppm | ASTM D5185m 23500 | 22320 | 19388 | 17490 |

CONTAMINANTS

| | method | limit/base | current | history1 | history2 |
|-----------|--------|------------------|--------------|----------|----------|
| Silicon | ppm | ASTM D5185m >25 | <1 | 0 | 0 |
| Sodium | ppm | ASTM D5185m | 14 | 18 | 16 |
| Potassium | ppm | ASTM D5185m >20 | 3 | <1 | 2 |
| Water | % | ASTM D6304 >0.05 | 0.019 | 0.025 | 0.020 |
| ppm Water | ppm | ASTM D6304 >500 | 193.4 | 252.9 | 203.4 |






FLUID CLEANLINESS

| | method | limit/base | current | history1 | history2 |
|-----------------|--------------|------------|-------------------|----------|----------|
| Particles >4µm | ASTM D7647 | | 8622 | 3858 | 4773 |
| Particles >6µm | ASTM D7647 | >1300 | ▲ 1470 | 504 | 584 |
| Particles >14µm | ASTM D7647 | >80 | 67 | 19 | 18 |
| Particles >21µm | ASTM D7647 | >20 | 16 | 4 | 3 |
| Particles >38µm | ASTM D7647 | >4 | 1 | 0 | 0 |
| Particles >71µm | ASTM D7647 | >3 | 0 | 0 | 0 |
| Oil Cleanliness | ISO 4406 (c) | >--/17/13 | ▲ 20/18/13 | 19/16/11 | 16/11 |

FLUID DEGRADATION

| | method | limit/base | current | history1 | history2 |
|------------------|----------|----------------|-------------|----------|----------|
| Acid Number (AN) | mg KOH/g | ASTM D8045 1.0 | 0.36 | 0.37 | 0.343 |


OIL ANALYSIS REPORT








| VISUAL | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| White Metal | scalar | *Visual | NONE | NONE | NONE |
| Yellow Metal | scalar | *Visual | NONE | NONE | NONE |
| Precipitate | scalar | *Visual | NONE | NONE | NONE |
| Silt | scalar | *Visual | NONE | NONE | NONE |
| Debris | scalar | *Visual | NONE | NONE | NONE |
| Sand/Dirt | scalar | *Visual | NONE | NONE | NONE |
| Appearance | scalar | *Visual | NORML | NORML | NORML |
| Odor | scalar | *Visual | NORML | NORML | NORML |
| Emulsified Water | scalar | *Visual | >0.05 | NEG | NEG |
| Free Water | scalar | *Visual | | NEG | NEG |

| FLUID PROPERTIES | method | limit/base | current | history1 | history2 |
|------------------|--------|------------|---------|----------|----------|
| Visc @ 40°C | cSt | ASTM D445 | 45 | 47.8 | 47.5 |

| SAMPLE IMAGES | method | limit/base | current | history1 | history2 |
|---------------|--------|------------|---------|----------|----------|
|---------------|--------|------------|---------|----------|----------|



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA000689 **Received** : 16 Oct 2023
Lab Number : 05980406 **Diagnosed** : 18 Oct 2023
Unique Number : 10697701 **Diagnostician** : Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

MURRELEKTRONIK INC
 1327 NORTHBROOK PKWY
 SUWANEE, GA
 US 30024
 Contact: D HILL
 dhill@murrinc.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)