

PROBLEM SUMMARY

Sample Rating Trend


ISO

KAESER SK 15T 8687556 (S/N 1513)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)

COMPONENT CONDITION SUMMARY



RECOMMENDATION

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS										
Sample Status			ABNORMAL	ATTENTION						
Particles >6μm	ASTM D7647	>1300	12500	▲ 1364						
Particles >14µm	ASTM D7647	>80	481	<u></u> 160						
Particles >21µm	ASTM D7647	>20	<u></u> ▲ 56	<u>42</u>						
Oil Cleanliness	ISO 4406 (c)	>/17/13	22/21/16	19/18/14						

Customer Id: SAWORL Sample No.: KC107041 Lab Number: 05980425 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS								
Action	Status	Date	Done By	Description				
Change Fluid			?	Oil and filter change at the time of sampling has been noted.				
Change Filter			?	Oil and filter change at the time of sampling has been noted.				

HISTORICAL DIAGNOSIS

06 Jun 2023 Diag: Jonathan Hester





No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






OIL ANALYSIS REPORT

KAESER SK 15T 8687556 (S/N 1513)

Compressor

KAESER SIGMA (OEM) M-460 (--- QTS)





DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Jun 2023	Oct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC107041	KC100939	
Sample Date		Client Info		10 Oct 2023	06 Jun 2023	
Machine Age	hrs	Client Info		3454	2169	
Oil Age	hrs	Client Info		3454	2169	
Oil Changed		Client Info		Changed	Not Changd	
Sample Status				ABNORMAL	ATTENTION	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	<1	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	0	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	10	8	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	3	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	20	47	
Calcium	ppm	ASTM D5185m	0	1	2	
Phosphorus	ppm	ASTM D5185m	0	<1	5	
Zinc	ppm	ASTM D5185m	0	23	17	
CONTAMINANTS	1	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	2	<1	
Sodium	ppm	ASTM D5185m		2	8	
Potassium	ppm	ASTM D5185m	>20	6	14	
Water	%	ASTM D6304	>0.05	0.013	0.019	
ppm Water	ppm	ASTM D6304	>500	138.7	193.0	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		25166	2925	
Particles >6µm		ASTM D7647	>1300	<u> </u>	<u>▲</u> 1364	
Particles >14μm		ASTM D7647	>80	481	<u>▲</u> 160	
Particles >21µm		ASTM D7647	>20	<u> </u>	<u>42</u>	
Particles >38μm		ASTM D7647	>4	2	4	
Particles >71μm		ASTM D7647		0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/21/16</u>	<u>19/18/14</u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.31	0.31	



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number **Unique Number** Test Package

: KC107041 : 05980425 : 10697720 : IND 2

: 16 Oct 2023 Received Diagnosed : 18 Oct 2023

Diagnostician : Don Baldridge 6450 KINGSPOINTE PKWY ORLANDO, FL US 32819

Contact:

T: F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)