

OIL ANALYSIS REPORT

Free Water

scalar *Visual

Area **LS-9300 QUINCY BU1105130087 - PACTIV** Component

Compressor

Recommendation

Resample at the next service interval to monitor.

Wear


All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





NORMAL


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH05980501		
Sample Date		Client Info		10 Oct 2023		
Machine Age	hrs	Client Info		94758		
Oil Age	hrs	Client Info		2727		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	<1		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		2		
Calcium	ppm	ASTM D5185m		1		
Phosphorus	ppm	ASTM D5185m		192		
Zinc	ppm	ASTM D5185m		2		
Sulfur	ppm	ASTM D5185m		434		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	3		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.50		
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		

----Contact/Location: SCOTT KEE - UCLEWCHANC

NEG



OIL ANALYSIS REPORT



no image no image Acid Number 0.55 0.50 0.45 (^b/HOX 0.35 ် 46 Ē 0.30 ₹ 3 44 ළ 은 0.25 2 0.20 42 P 0.15 0.10 40 0.05 38 0.00 0ct10/23 0ct10/23 LEWIS SYSTEM AND SERVICES CO Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513 Sample No. : UCH05980501 Received : 16 Oct 2023 3915 SHOPTON RD Lab Number : 05980501 : 18 Oct 2023 CHARLOTTE, NC Diagnosed Unique Number : 10697796 Diagnostician : Jonathan Hester US 28217 Test Package : IND 2 Contact: SCOTT KEE To discuss this sample report, contact Customer Service at 1-800-237-1369. skee@lewissystemsinc.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. T: (704)588-2299 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: Contact/Location: SCOTT KEE - UCLEWCHANC

42.4

no image

no image

Certificate L2367

Page 2 of 2