

# **PROBLEM SUMMARY**


Sample Rating Trend

ISO

# KAESER CSD 100ST 6226466 (S/N 1117)


Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)





### **COMPONENT CONDITION SUMMARY**



### RECOMMENDATION

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

PROBLEMATIC TEST RESULTS									
Sample Status			ABNORMAL	NORMAL	ATTENTION				
Particles >6µm	ASTM D7647	>1300	<b>4</b> 2427	1073	1109				
Particles >14µm	ASTM D7647	>80	<b>189</b>	70	<b>4</b> 94				
Particles >21µm	ASTM D7647	>20	<u>▲</u> 52	20	<u>^</u> 24				
Oil Cleanliness	ISO 4406 (c)	>/17/13	<b>20/18/15</b>	19/17/13	19/17/14				

**Customer Id: SPRBET** Sample No.: KC108901 Lab Number: 05981244 Test Package: IND 2

To manage this report scan the QR code

To discuss the diagnosis or test data: Jonathan Hester +1 919-379-4092 x4092 ihester@wearcheckusa.com

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

### **RECOMMENDED ACTIONS**

There are no recommended actions for this sample.

### HISTORICAL DIAGNOSIS

### 12 Apr 2023 Diag: Angela Borella

NORMAL



The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



### 15 Sep 2022 Diag: Don Baldridge

ISO



Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. All component wear rates are normal. There is a moderate amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



### 20 Apr 2022 Diag: Jonathan Hester

WEAR




No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. The aluminum level is abnormal. All other component wear rates are normal. There is a high amount of particulates present in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER CSD 100ST 6226466 (S/N 1117)

Component

Compressor

KAESER SIGMA (OEM) FG-460 (--- GAL)

## **DIAGNOSIS**

### Recommendation

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

## Contamination

There is a high amount of particulates present in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2018	eb2019 Nov2019	Jun 2020 Oct 2021 Sep 2022	Oct2023	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC108901	KC110999	KC98766
Sample Date		Client Info		10 Oct 2023	12 Apr 2023	15 Sep 2022
Machine Age	hrs	Client Info		36005	31952	29537
Oil Age	hrs	Client Info		4053	2415	2750
Oil Changed		Client Info		Not Changd	N/A	Changed
Sample Status				ABNORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	2	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	4	10	2
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	2	2	<1
Tin	ppm	ASTM D5185m	>10	0	0	0
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	1
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		0	0	<1
Calcium	ppm	ASTM D5185m		0	0	0
Phosphorus	ppm	ASTM D5185m	500	63	189	33
Zinc	ppm	ASTM D5185m		<1	0	4
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	0
Sodium	ppm	ASTM D5185m		<1	0	0
Potassium	ppm	ASTM D5185m	>20	0	0	<1
Water	%	ASTM D6304	>0.05	0.003	0.006	0.007
ppm Water	ppm	ASTM D6304	>500	35.0	65.7	73.5
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		9081	4164	4017
Particles >6µm		ASTM D7647	>1300	<u> </u>	1073	1109
Particles >14µm		ASTM D7647	>80	<b>189</b>	70	<b>4</b> 94
Particles >21µm		ASTM D7647	>20	<u>^</u> 52	20	<u>^</u> 24
Particles >38μm		ASTM D7647	>4	3	1	1
Particles >71μm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 20/18/15	19/17/13	<b>△</b> 19/17/14
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.5	0.41	0.71	0.34



# **OIL ANALYSIS REPORT**



Certificate L2367

Test Package

: IND 2

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: F:

Contact: SERVICE MANAGER