




FUEL REPORT

Sample Rating Trend

NORMAL



Machine Id
FAST-C - PUMP NOZZLE
 Component
Diesel Fuel
 Fluid
DIESEL FUEL No. 1 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a moderate amount of particulates present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC0869455	WCDF01936	---
Sample Date	Client Info			04 Oct 2023	17 Oct 2019	---
Machine Age	hrs	Client Info		0	0	---
Sample Status				NORMAL	NORMAL	---

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.838	0.840	---
Fuel Color	text	*Visual Screen		Yellow	Yellow	---
ASTM Color	scalar	*ASTM D1500		L3.0	L1.0	---
Visc @ 40°C	cSt	ASTM D445	2.4	2.4	2.51	---
Pensky-Martens Flash Point	°C	*PMCC Calculated		55	64	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0	11	---
Sulfur (UVF)	ppm	ASTM D5453		8	8	---






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		154	161	---
5% Distillation Point	°C	ASTM D86		186	188	---
10% Distill Point	°C	ASTM D86		198	199	---
15% Distillation Point	°C	ASTM D86		207	208	---
20% Distill Point	°C	ASTM D86		215	218	---
30% Distill Point	°C	ASTM D86		230	232	---
40% Distill Point	°C	ASTM D86		245	247	---
50% Distill Point	°C	ASTM D86		258	261	---
60% Distill Point	°C	ASTM D86		273	275	---
70% Distill Point	°C	ASTM D86		287	290	---
80% Distill Point	°C	ASTM D86		303	305	---
85% Distillation Point	°C	ASTM D86		313	315	---
90% Distill Point	°C	ASTM D86		325	326	---
95% Distillation Point	°C	ASTM D86		342	343	---
Final Boiling Point	°C	ASTM D86		350	352	---
Distillation Residue	%	ASTM D86		1.4	1.4	---
Distillation Loss	%	ASTM D86		0.9	0.8	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		37.4	37.0	---
Cetane Index		ASTM D4737	<40.0	48.7	48.3	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	<1	---
Sodium	ppm	ASTM D5185m	<0.1	0	0	---
Potassium	ppm	ASTM D5185m	<0.1	<1	0	---
Water	%	ASTM D6304	<0.05	0.003	0.003	---
ppm Water	ppm	ASTM D6304	<500	37.5	38.1	---
% Gasoline	%	*In-House	<0.50	0.0	0.0	---
% Biodiesel	%	*In-House	<20.0	0.0	0.0	---



FUEL REPORT





FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	1542	---	---
Particles >6µm	ASTM D7647	>640	567	---	---
Particles >14µm	ASTM D7647	>80	104	---	---
Particles >21µm	ASTM D7647	>20	43	---	---
Particles >38µm	ASTM D7647	>4	5	---	---
Particles >71µm	ASTM D7647	>3	1	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	18/16/14	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m <0.1	0	0	---
Nickel	ppm	ASTM D5185m <0.1	0	0	---
Lead	ppm	ASTM D5185m <0.1	0	0	---
Vanadium	ppm	ASTM D5185m <0.1	0	0	---
Iron	ppm	ASTM D5185m <0.1	0	0	---
Calcium	ppm	ASTM D5185m <0.1	<1	1	---
Magnesium	ppm	ASTM D5185m <0.1	0	0	---
Phosphorus	ppm	ASTM D5185m <0.1	6	3	---
Zinc	ppm	ASTM D5185m <0.1	0	0	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0869455 **Received** : 17 Oct 2023
Lab Number : **05981542** **Diagnosed** : 25 Oct 2023
Unique Number : 10698837 **Diagnostician** : Doug Bogart
Test Package : DF-2 (Additional Tests: Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

VITAL FUEL SYSTEMS
 1076 CLASSIC RD
 APEX, NC
 US 27539
 Contact: JOHN MORREALE
 jmorreale@vitalfuelsystems.com
 T: (919)629-8180
 F: (919)303-7399