

FUEL REPORT

Sample Rating Trend

VIS DEBRIS



DUKE RALEIGH AST-1

Component

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR)

DIAGNOSIS

Recommendation

We advise that you filter this fluid before use. All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

Moderate concentration of visible dirt/debris present in the fuel. The water content is negligible. There is no bacteria or fungus (yeast and/or mold) present in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

R) (GAL)			Dec2021	Oct2023		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0869451	WC0643834	
Sample Date		Client Info		10 Oct 2023	09 Dec 2021	
Machine Age	hrs	Client Info		0	0	
Sample Status				ABNORMAL	SEVERE	
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	0.839	0.838	0.834	
Fuel Color	text	*Visual Screen	Yllow	Red	Red	
ASTM Color	scalar	*ASTM D1500		L4.5	L5.0	
Visc @ 40°C	cSt	ASTM D445	3.0	2.4	2.32	
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	58	60	
SULFUR CONTE	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	0	4	
Sulfur (UVF)	ppm	ASTM D5453		7	8	
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	162	168	
5% Distillation Point	°C	ASTM D86		187	189	
10% Distill Point	°C	ASTM D86	201	196	197	
15% Distillation Point	°C	ASTM D86		203	203	
20% Distill Point	°C	ASTM D86	216	212	210	
30% Distill Point	°C	ASTM D86	230	227	224	
40% Distill Point	°C	ASTM D86	243	242	238	
50% Distill Point	°C	ASTM D86	255	257	252	
60% Distill Point	°C	ASTM D86	267	272	268	
70% Distill Point	°C	ASTM D86	280	289	285	
80% Distill Point	°C	ASTM D86	295	306	305	
85% Distillation Point	°C	ASTM D86		316	315	
90% Distill Point	°C	ASTM D86	310	327	326	
95% Distillation Point	°C	ASTM D86		342	340	
Final Boiling Point	°C	ASTM D86	341	349	351	
Distillation Residue	%	ASTM D86	3.0	1.4	1.4	
Distillation Loss	%	ASTM D86	3.0	0.9	0.4	
IGNITION QUALIT	ΓΥ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	37.4	38.2	
Cetane Index		ASTM D4737	<40.0	48.4	48.8	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0	0	
Sodium	ppm	ASTM D5185m	<0.1	0	0	
Potassium	ppm	ASTM D5185m	< 0.1	<1	<1	
Water	%	ASTM D6304	< 0.05	0.012	0.012	
ppm Water	ppm	ASTM D6304	< 500	121.7	121.3	
% Gasoline	%	*In-House	< 0.50	0.0	0.0	
% Biodiesel	%	*In-House	<20.0	3.2	4.2	



FUEL REPORT







Certificate L2367

Laboratory Sample No. Lab Number Unique Number

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : WC0869451 : 05981544

Received : 10698839

: 17 Oct 2023 Diagnosed : 25 Oct 2023 Diagnostician : Doug Bogart

Test Package : DF-2 (Additional Tests: Bacteria, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) **VITAL FUEL SYSTEMS**

1076 CLASSIC RD APEX, NC US 27539

Contact: JOHN MORREALE jmorreale@vitalfuelsystems.com

T: (919)629-8180 F: (919)303-7399

Contact/Location: JOHN MORREALE - VITAPE