

FUEL REPORT

Sample Rating Trend

NORMAL

GOOGLE-LNR-B-1-K

Diesel Fuel Fluid DIESEL FUEL No. 2 (--- GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

				Oct2023		
SAMPLE INFORM	1ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0862205		
Sample Date		Client Info		05 Oct 2023		
Machine Age	hrs	Client Info		0		
Sample Status				NORMAL		
PHYSICAL PROP	ERTIES	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298		0.844		
Fuel Color	text	*Visual Screen		Red		
ASTM Color	scalar	*ASTM D1500		L4.5		
Visc @ 40°C	cSt	ASTM D445	4.1	2.49		
Pensky-Martens Flash Point	°C	*PMCC Calculated		61		
SULFUR CONTER	NT	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		0		
Sulfur (UVF)	ppm	ASTM D5453		10		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86		168		
5% Distillation Point	°C	ASTM D86		193		
10% Distill Point	°C	ASTM D86		203		
15% Distillation Point	°C	ASTM D86		211		
20% Distill Point	°C	ASTM D86		219		
30% Distill Point	°C	ASTM D86		234		
40% Distill Point	°C	ASTM D86		248		
50% Distill Point	°C	ASTM D86		261		
60% Distill Point	°C	ASTM D86		275		
70% Distill Point	°C	ASTM D86		288		
80% Distill Point	°C	ASTM D86		304		
85% Distillation Point	°C	ASTM D86		313		
90% Distill Point	°C	ASTM D86		324		
95% Distillation Point	°C	ASTM D86		341		
Final Boiling Point	°C	ASTM D86		348		
Distillation Residue	%	ASTM D86		1.4		
Distillation Loss	%	ASTM D86		0.7		
IGNITION QUALIT	ΓY	method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.2		
Cetane Index		ASTM D4737	<40.0	47.3		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	<0.1	0		
Potassium	ppm	ASTM D5185m	<0.1	<1		
Water	%	ASTM D6304	< 0.05	0.006		
ppm Water	ppm	ASTM D6304	<500	64.1		
% Gasoline	%	*In-House	<0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT






FLUID CLEANLI	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>2500	1399		
Particles >6µm		ASTM D7647	>640	428		
Particles >14µm		ASTM D7647	>80	65		
Particles >21µm		ASTM D7647	>20	25		
Particles >38µm		ASTM D7647	>4	1		
Particles >71µm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>18/16/13	18/16/13		
HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	2		
Nickel	ppm	ASTM D5185m	<0.1	0		
Lead	ppm	ASTM D5185m	<0.1	0		
Vanadium	ppm	ASTM D5185m	<0.1	0		
Iron	ppm	ASTM D5185m	<0.1	0		
Calcium	ppm	ASTM D5185m	<0.1	<1		
Magnesium	ppm	ASTM D5185m	<0.1	<1		
Phosphorus	ppm	ASTM D5185m	<0.1	0		
Zinc	ppm	ASTM D5185m	<0.1	0		
SAMPLE IMAGE	S	method	limit/base	current	history1	history2
Color					no image	no image
Bottom			(no image	no image



30%

40% 20% %09 %0L 80% 90% %00




Laboratory

Sample No.

Lab Number







VITAL FUEL SYSTEMS 1076 CLASSIC RD APEX, NC US 27539 Contact: JOHN MORREALE jmorreale@vitalfuelsystems.com T: (919)629-8180 F: (919)303-7399



3

cles (1 ml) 12 cles

The 2k

b 1

Ωk

Ē 3 21 Sal

'E 21

ັຍ 1k

11

0

0ct5/23

Certificate L2367

Contact/Location: JOHN MORREALE - VITAPE