




# FUEL REPORT

Sample Rating Trend



**WATER**



Machine Id  
**FAST-C - PUMP NOZZLE**

Component  
**Gasoline**  
Fluid  
**NOT GIVEN (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

This is a baseline read-out on the submitted sample.

### ▲ Contamination

There is a light concentration of water present in the gasoline.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC0869453</b>	---	---
Sample Date	Client Info		<b>11 Oct 2023</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Oil Age	hrs	Client Info	<b>0</b>	---	---
Oil Changed	Client Info		<b>N/A</b>	---	---
Sample Status			<b>ABNORMAL</b>	---	---

## CONTAMINANTS


	method	limit/base	current	history1	history2
Water	%	ASTM D6304	<0.05	▲ <b>0.203</b>	---
ppm Water	ppm	ASTM D6304	<500	▲ <b>2038.8</b>	---
% Gasoline	%	*In-House	<0.50	<b>100.0</b>	---
% Biodiesel	%	*In-House	<20.0	<b>0.0</b>	---

## SAMPLE IMAGES

	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image



# FUEL REPORT



## GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0869453  
**Lab Number** : 05981570  
**Unique Number** : 10698865  
**Test Package** : DF-2 ( Additional Tests: API, CC Flash, Cetane, Color-ASTM, Fuel, GC-PercFuel, ICP, KF, KV40, Pri

**VITAL FUEL SYSTEMS**  
 1076 CLASSIC RD  
 APEX, NC  
 US 27539

To discuss this sample report, contact Customer Service at 1-800-237-1369.

**Contact:** JOHN MORREALE  
 jmorreale@vitalfuelsystems.com

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T: (919)629-8180  
 F: (919)303-7399