

COOLANT REPORT

AURORA [200006927] Machine Id 10WEA87214 - A02 - A (S/N 11246697)

Component

Coolant

CLARIANT ANTIFROGEN N (--- LTR)

Sample Rating Trend



DIAGNOSIS	
Recommendation	
The fluid is suitable for further service.	
Corrosion	
All motal loyals are permal indicating no correction	

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX05981638		
Sample Date		Client Info		10 May 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	1.11	1.070		
рН	Scale 0-14	ASTM D1287	8.5	8.11		
Nitrites	ppm	AP-053:2009		412		
Reserve Alkalinity	Scale 0-20	*ASTM D1121	4.0			
Percentage Glycol	%	ASTM D3321	44	52.6		
Freezing Point	°F	ASTM D3321	-32	-40		
Total Dissolved Solids				261.0		
Carboxylate				n/a		
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	3	<1		
Phosphorus	ppm	ASTM D6130	5	16		
Boron	ppm	ASTM D6130	15	0		
Molybdenum	ppm	ASTM D6130	110	142		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	0		
Aluminum	ppm	ASTM D6130	>10	0		
Copper	ppm	ASTM D6130	>10	0		
Lead	ppm	ASTM D6130	>10	0		
Tin	ppm	ASTM D6130	>10	0		
Zinc	ppm	ASTM D6130		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		0		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130	2400	3253		
Potassium	ppm	ASTM D6130	5	0		
SCALE POTENTI	AL _	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		10		
Magnesium	ppm	ASTM D6130		<1		



COOLANT REPORT





GRAPHS		
Iron/Tin/Silver	Reserve Alkalinity	/
Abnormal iron	Abnormal 12	
annonnanna Silver		
-	10	
	Akaii	
	Reserve Alkalinity	
	4	
!	2 Abnormal	
23	370	
May 10,723	May10/23 May10/23	
Çopper/Aluminum/Lead	Freeze Point	
copper	10	
••••••••••••••••••••••••••••••••••••••	0	
	_G -10	
	-50 hit	
-	-30 -	
	-30	
-	40	
	-50	
May 10,23	May10/23 May10/23	
pH	Nitrites	
	3000 Abnormal	
Abnormal	2500	
-	2000	
Abnomal		
-	道 1500 -	
	1000 - Abnormal	
	500	
	0	
May10/23 -	May10,23 +	
1/4	ay1	



Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10698933

: NX05981638 : 05981638

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received Diagnosed

: 17 Oct 2023 : 30 Oct 2023 Diagnostician : Jonathan Hester Test Package : COOL- (Additional Tests: COOL, ICP)

NORDEX USA - Chicago 300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL US 60606 Contact: DEVIN LINEHAN

DLinehan@nordex-online.com T: (312)386-4124

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (312)386-7102

Contact/Location: DEVIN LINEHAN - NORDEX