

COOLANT REPORT

AURORA [200006927] Machine Id 31WEA87235 - C05 - A (S/N 7807693)

Component

Coolant

CLARIANT ANTIFROGEN N (--- LTR)

Sample Rating Trend



_				
Reco	m	m	nd	a

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX05981643		
Sample Date		Client Info		12 Jun 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	1.11	1.056		
рН	Scale 0-14	ASTM D1287	8.5	8.17		
Nitrites	ppm	AP-053:2009		448		
Reserve Alkalinity	Scale 0-20	*ASTM D1121	4.0			
Percentage Glycol	%	ASTM D3321	44	41.7		
Freezing Point	°F	ASTM D3321	-32	-15		
Total Dissolved Solids				224.0		
Carboxylate				n/a		
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	3	<1		
Phosphorus	ppm	ASTM D6130	5	16		
Boron	ppm	ASTM D6130	15	0		
Molybdenum	ppm	ASTM D6130	110	126		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	3		
Aluminum	ppm	ASTM D6130	>10	<1		
Copper	ppm	ASTM D6130	>10	0		
Lead	ppm	ASTM D6130	>10	0		
Tin	ppm	ASTM D6130	>10	0		
Zinc	ppm	ASTM D6130		<1		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		0		
CARRIER SALTS	;	method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130	2400	2833		
Potassium	ppm	ASTM D6130	5	0		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		0		
Magnesium	ppm	ASTM D6130		0		
	P P					



COOLANT REPORT





GRAPHS		
Iron/Tin/Silver	Reserve Alkalinity	
Abnormal	Abnormal	
** ***********************************	12 6	
)	10	
3+	Reserve Alkalinity	
·	a.a.sa	
	4	
2+	2 - Abnormal	
)	0	
Jun12/23	Jun 12/23 Jun 12/23	
Copper/Aluminum/Lead	Freeze Point	
Abriofinal	10	
**************************************	5-	
+	0	
	Freeza Point (°C)	
	2g-10	
+	-15	
-	-20	
	-25	
Jun12/23	Jun12/23	
pH	ਤੋਂ Nitrites	
T:	3000 Abnormal	
Ahnomal	2500	
Abnormal		
Abnormal	2000	
	Nitit 2000 -	
	1000 - Abnormal	
!	500+	
Jun12/23	Jun 12/23 Jun 12/23	



Laboratory Sample No. Lab Number Unique Number : 10698938

: NX05981643 : 05981643

To discuss this sample report, contact Customer Service at 1-800-237-1369.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 17 Oct 2023

Diagnosed : 30 Oct 2023 Diagnostician : Jonathan Hester Test Package : COOL- (Additional Tests: COOL, ICP)

NORDEX USA - Chicago

300 SOUTH WACKER DRIVE, SUITE 1500 CHICAGO, IL US 60606

Contact/Location: DEVIN LINEHAN - NORDEX

Contact: DEVIN LINEHAN DLinehan@nordex-online.com

T: (312)386-4124

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (312)386-7102