


## **COOLANT REPORT**

# AURORA [200006927] Machine Id 16WEA87220 - I02 - A (S/N 11246701)

Component

Coolant

**CLARIANT ANTIFROGEN N (--- LTR)** 





#### DIAGNOSIS

#### Recommendation

The fluid is suitable for further service.

#### Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

#### Contaminants

There is no indication of any contamination in the coolant.


#### **Coolant Condition**

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX05981653		
Sample Date		Client Info		26 Jun 2023		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				NORMAL		
PHYSICAL TEST F	RESULTS	method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	1.11	1.062		
pH	Scale 0-14	ASTM D1287	8.5	8.23		
Nitrites	ppm	AP-053:2009		372		
Reserve Alkalinity	Scale 0-20	*ASTM D1121	4.0			
Percentage Glycol	%	ASTM D3321	44	45.6		
Freezing Point	°F	ASTM D3321	-32	-24		
Total Dissolved Solids				279.0		
Carboxylate				n/a		
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130	3	<1		
Phosphorus	ppm	ASTM D6130	5	17		
Boron	ppm	ASTM D6130	15	0		
Molybdenum	ppm	ASTM D6130	110	127		
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	<1		
Aluminum	ppm	ASTM D6130	>10	0		
Copper	ppm	ASTM D6130	>10	0		
Lead	ppm	ASTM D6130	>10	0		
Tin	ppm	ASTM D6130	>10	0		
Zinc	ppm	ASTM D6130		0		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		0		
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130	2400	3005		
Potassium	ppm	ASTM D6130	5	0		
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		<1		
Magnesium	ppm	ASTM D6130		0		



### **COOLANT REPORT**





Iron/Tin/Silver	Reserve Alkalinity	
Abnormat ,	14 T	
iron	12 Abnormal	
••••••silver	10	
	Reserve Alkalinity	
	Sec. 2	
	4	
:	2 - Abnormal	
233		
Jun26/23	Jun26/23 Jun26/23	
	Freeze Point	
Copper/Aluminum/Lead	10 <sub>T</sub> :	
copper	5	
••••••••••••••••••••••••••••••••••••••	0-	
1	S -5	
	Feeze Point (°C)	
	82 -15 <b>-</b>	
1	-20 <del>-</del>	
	-25	
	-30 +	
m	-35	
Jun 26/23	Jun 26/23 Jun 26/23	
pH	Nitrites	
	Abnormal	
Abnormal	2500 +	
	2000	
Abnormal		
	## 1500 <b>-</b>	
1		
1	Abnormal	
Li	500 +	
Jun26/23 千	Jun26/23 +	





Certificate L2367

Laboratory Sample No. Lab Number Unique Number : 10698948 Test Package : COOL- ( Additional Tests: COOL, ICP )

: NX05981653 : 05981653

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 17 Oct 2023 Diagnosed : 30 Oct 2023 Diagnostician : Jonathan Hester

**NORDEX USA - Chicago** 300 SOUTH WACKER DRIVE, SUITE 1500 CHICAGO, IL

US 60606 Contact: DEVIN LINEHAN

DLinehan@nordex-online.com

T: (312)386-4124 F: (312)386-7102

To discuss this sample report, contact Customer Service at 1-800-237-1369. \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)